

RICHMOND VALLEY COUNCIL POLICY REGISTER

Policy No: 3.18.2

Reference: Roads - Street Management; Development and Building Controls - Policy; Energy Supply and Telecommunications - Maintenance

POLICY:	UNDER AWNING LIGHTING
FUNCTION:	Development Assessment/Street Lighting
OBJECTIVE:	To require under awning lighting to be connected to the private electricity supply circuit.
DIRECTORATE:	ENVIRONMENTAL DEVELOPMENT SERVICES/WORKS

POLICY

1. All future under awning lighting shall be connected to the private electricity supply of the property responsible for the awning.
2. Existing under awning lighting connected to the street lighting circuit will remain connected to the existing supply until such time as work is undertaken on the property that infringes on the awning or lighting, or a development application is received for the property that warrants the change in supply connection being incorporated into the work.
3. Consideration will be given in the assessment of the development application for a requirement to reconnect any existing under awning lighting from the street lighting circuit to the private property electricity supply.

VARIATION

Council reserves the right to review, vary and/or revoke this Policy from time to time.