



## Certificate Of Analysis

**Client:** Richmond Valley Council

**Address:** Locked Bag 10  
Casino NSW 2470

**Contact:** Aidan Macqueen

**Sampled by:** Jacob Arthur / Mia Donnelly

\* **Subcontract Laboratory:** Envirolab (NATA2901)

\* **Subcontract Reference:** 163674

*Sampled in accordance with RWL 2.0 to 2.05*

Final report

RVC Casino Consumer Monthly

**Report no:** 17/0433

**Date received:** 14/03/2017

**Testing commenced:** 14/03/2017

**Date reported:** 21/04/2017

**No. of samples:** 3

**Revision no:** 01

Sample No.: Sample description:  Date sampled:	Unit	Method	LOR	17/0433/1 Casino Walker Street 14/03/2017	17/0433/2 Casino Showground 14/03/2017	17/0433/3 Casino South Res 14/03/2017
Fluoride - ISE	mg/L	APHA4500FC	0.05	1.03	1.04	1.05
Colour (True)	Pt-Co	RWL10.02	2	<2	<2	<2
Ammonia-N	mg/L	RWL 10.06	0.01	<0.01	<0.01	<0.01
Nitrogen - Nitrate-N	mg/L	RWL 10.05	0.05	<0.05	<0.05	<0.05
Nitrogen - Nitrite-N	mg/L	RWL 10.05	0.01	<0.01	<0.01	<0.01
Aluminium (Total)	mg/L	APHA3120B	0.005	0.061	0.050	0.054
Copper (Total)	mg/L	APHA3120B	0.005	0.034	0.035	<0.005
Iron (Total)	mg/L	APHA3120B	0.005	0.02	<0.005	<0.005
Lead (Total)	mg/L	APHA3120B	0.005	<0.005	<0.005	<0.005
Manganese (Total)	mg/L	APHA3120B	0.005	<0.005	<0.005	<0.005
Zinc (Total)	mg/L	APHA3120B	0.005	0.011	<0.005	<0.005
Total Trihalomethanes*	µg/L	Envirolab	1	80	115	84



## Certificate Of Analysis

**Client:** Richmond Valley Council

**Report no:** 17/0433

**General comments:** This report must not be reproduced except in full. This report relates only to items tested as specified herein. Samples analysed between date received and date reported. Accredited for compliance with ISO/IEC 17025. # NATA accreditation does not cover the performance of this service. Tests marked with \* are subcontracted. LOR denotes 'Limit of Reporting'

**Specific comments:** This report has been re-issued because the sampling date was incorrect. This report supersedes any previous report with this Report Number (see top right of this page).

A. Hawthorne  
Laboratory Manager  
Approved Authoriser