



Certificate Of Analysis

Client: Richmond Valley Council

Address: Locked Bag 10
Casino NSW 2470

Contact: Aidan Macqueen

Sampled by: Mia Donnelly

* **Subcontract Laboratory:** Envirolab (NATA2901)

* **Subcontract Reference:** 171335

Sampled in accordance with RWL 2.0 to 2.05

Final report

RVC Casino Consumer Monthly

Report no: 17/1125

Date received: 11/07/2017

Testing commenced: 11/07/2017

Date reported: 21/07/2017

No. of samples: 2

Revision no: 00

Sample No.: Sample description: Date sampled:	Unit	Method	LOR	17/1125/1 Casino Walker Street 11/07/2017	17/1125/2 Casino Sextonville Rd 11/07/2017
Fluoride - ISE	mg/L	APHA4500FC	0.05	0.97	1.01
Colour (True)	Pt-Co	RWL10.02	2	2	<2
Ammonia-N	mg/L	RWL 10.06	0.01	<0.01	<0.01
Nitrogen - Nitrate-N	mg/L	RWL 10.05	0.05	0.19	0.21
Nitrogen - Nitrite-N	mg/L	RWL 10.05	0.01	<0.01	<0.01
Aluminium (Total)	mg/L	APHA3120B	0.005	0.15	0.25
Copper (Total)	mg/L	APHA3120B	0.005	0.018	<0.005
Iron (Total)	mg/L	APHA3120B	0.005	0.02	0.04
Lead (Total)	mg/L	APHA3120B	0.005	<0.005	<0.005
Manganese (Total)	mg/L	APHA3120B	0.005	<0.005	0.008
Zinc (Total)	mg/L	APHA3120B	0.005	<0.005	<0.005
Total Trihalomethanes*	µg/L	Envirolab	1	78	119



Certificate Of Analysis

Client: Richmond Valley Council

Report no: 17/1125

General comments: This report must not be reproduced except in full. This report relates only to items tested as specified herein.
Samples analysed between date received and date reported. Accredited for compliance with ISO/IEC 17025.
NATA accreditation does not cover the performance of this service. Tests marked with * are subcontracted.
LOR denotes 'Limit of Reporting'

Specific comments:

V. Barnett
Laboratory Analyst
Approved Authoriser