



## Certificate Of Analysis

**Client:** Richmond Valley Council  
**Address:** Locked Bag 10  
Casino NSW 2470  
**Contact:** Aidan Macqueen  
**Sampled by:** M. Macrae  
**Subcontract Laboratory:** Envirolab (NATA2901)  
**Subcontract Reference:** 167955  
*Analysis results apply to samples as received.*

Final report

**Report no:** 17/0819  
**Date received:** 23/05/2017  
**Testing commenced:** 23/05/2017  
**Date reported:** 5/06/2017  
**No. of samples:** 2  
**Revision no:** 00

Raw and Finished Weekly

Sample No.: Sample description:  Date sampled:	Unit	Method	LOR	17/0819-1 RVC Finished Water 23/05/2017	17/0819-2 RVC Raw Water 23/05/2017
pH	pH	APHA4500H		7.7	7.7
Electrical Conductivity	µS/cm	APHA2510B	1	456	290
Total Dissolved Solids by calc	mg/L	APHA1030E	2	292	186
Dissolved Oxygen	mg/L	APHA4500OG	0.2	9.2	8.7
Fluoride - ISE	mg/L	APHA4500FC	0.05	1.07	[NA]
Colour (Apparent)	Pt-Co	RWL10.02	2	<2	130
Colour (True)	Pt-Co	RWL10.02	2	<2	48
Turbidity	NTU	APHA2130B	0.1	<0.10	23
Alkalinity (as CaCO3)	mg/L	APHA2320B	20	129	106
Suspended Solids	mg/L	APHA2540D	1	1	19
Total Organic Carbon*	mg/L	Envirolab	1	4	7
Aluminium (Total)	mg/L	APHA3120B	0.005	0.048	1.38
Aluminium (Dissolved)	mg/L	APHA3120B	0.005	0.048	0.27
Iron (Total)	mg/L	APHA3120B	0.005	<0.005	1.7



## Certificate Of Analysis

**Client:** Richmond Valley Council

**Report no:** 17/0819

Sample No.: Sample description: Date sampled:	Unit	Method	LOR	17/0819-1 RVC Finished Water 23/05/2017	17/0819-2 RVC Raw Water 23/05/2017
Iron (Dissolved)	mg/L	APHA3120B	0.005	<0.005	0.32
Manganese (Total)	mg/L	APHA3120B	0.005	<0.005	0.039
Manganese (Dissolved)	mg/L	APHA3120B	0.005	<0.005	0.009
Calcium	mg/L	APHA3120B	0.1	20.7	21.0
Magnesium	mg/L	APHA3120B	0.1	13.3	13.6
Hardness as CaCO <sub>3</sub>	mg/L	APHA2340B	1	106	108
Total Coliforms	MPN/100mL	APHA9223B	1	<1	15,531
<i>E.coli</i>	MPN/100mL	APHA9223B	1	<1	308
Heterotrophic Plate Count	MPN/mL	APHA9215E	2	<2	1,080

General comments: This report must not be reproduced except in full. This report relates to items tested as specified herein.  
Samples tested between date received and date reported. Accredited for compliance with ISO/IEC 17025.  
# NATA accreditation does not cover the performance of this service. Tests marked with \* are subcontracted.  
LOR denotes 'Limit of Reporting'

Specific comments:

V. Barnett  
Laboratory Analyst  
Approved Authoriser