



## Certificate Of Analysis

**Client:** Richmond Valley Council  
**Address:** Locked Bag 10  
Casino NSW 2470  
**Contact:** Aidan Macqueen  
**Sampled by:** Wayne Orton  
**Subcontract Laboratory:** Envirolab (NATA2901)  
**Subcontract Reference:** 172756

Final report

**Report no:** 17/1202  
**Date received:** 25/07/2017  
**Testing commenced:** 25/07/2017  
**Date reported:** 14/08/2017  
**No. of samples:** 2  
**Revision no:** 01

*Analysis results apply to samples as received.*

Raw and Finished Weekly

Sample No.: Sample description:  Date sampled:	Unit	Method	LOR	17/1202-1 RVC Finished Water 25/07/2017	17/1202-2 RVC Raw Water 25/07/2017
pH	pH	APHA4500H		7.4	7.7
Electrical Conductivity	µS/cm	APHA2510B	1	338	294
Total Dissolved Solids by calc	mg/L	APHA1030E	2	216	188
Dissolved Oxygen	mg/L	APHA4500OG	0.2	10.5	9.8
Fluoride - ISE	mg/L	APHA4500FC	0.05	1.08	[NA]
Colour (Apparent)	Pt-Co	RWL10.02	2	<2	64
Colour (True)	Pt-Co	RWL10.02	2	<2	12
Turbidity	NTU	APHA2130B	0.1	<0.10	16
Alkalinity (as CaCO <sub>3</sub> )	mg/L	APHA2320B	20	96	103
Suspended Solids	mg/L	APHA2540D	1	<1	45
Total Organic Carbon*	mg/L	Envirolab	1	2	4
Aluminium (Total)	mg/L	APHA3120B	0.005	0.078	1.21
Aluminium (Dissolved)	mg/L	APHA3120B	0.005	0.065	0.084
Iron (Total)	mg/L	APHA3120B	0.005	<0.005	1.7



## Certificate Of Analysis

**Client:** Richmond Valley Council

**Report no:** 17/1202

Sample No.: Sample description: Date sampled:	Unit	Method	LOR	17/1202-1 RVC Finished Water 25/07/2017	17/1202-2 RVC Raw Water 25/07/2017
Iron (Dissolved)	mg/L	APHA3120B	0.005	<0.005	0.079
Manganese (Total)	mg/L	APHA3120B	0.005	<0.005	0.054
Manganese (Dissolved)	mg/L	APHA3120B	0.005	<0.005	0.01
Calcium	mg/L	APHA3120B	0.1	21.6	21.4
Magnesium	mg/L	APHA3120B	0.1	13.3	13.6
Hardness as CaCO <sub>3</sub>	mg/L	APHA2340B	1	109	109
Total Coliforms	MPN/100mL	APHA9223B	1	<1	466
<i>E.coli</i>	MPN/100mL	APHA9223B	1	<1	34
Heterotrophic Plate Count	MPN/mL	APHA9215E	2	<2	380

General comments: This report must not be reproduced except in full. This report relates to items tested as specified herein.  
Samples tested between date received and date reported. Accredited for compliance with ISO/IEC 17025.  
# NATA accreditation does not cover the performance of this service. Tests marked with \* are subcontracted.  
LOR denotes 'Limit of Reporting'

Specific comments: This is the final report that supersedes the preliminary report issued on the 09.08.17

V. Barnett  
Laboratory Analyst  
Approved Authoriser