



Certificate Of Analysis

Client: Richmond Valley Council
Address: Locked Bag 10
Casino NSW 2470
Contact: Aidan Macqueen
Sampled by: Mia Donnelly

Final report

Report no: 17/1526 00
Date received: 19/09/2017
Testing commenced: 19/09/2017
Date reported: 27/09/2017
No. of samples: 3


Sampled in accordance with RWL 2.0 to 2.05

Weekly Fluoride

Sample No.:	Unit	Method	LOR	17/1526/1	17/1526/2	17/1526/3
Sample description:				Casino Walker Street	Casino North Res	Casino Sheppard St
Date sampled:				19/09/2017	19/09/2017	19/09/2017
Fluoride - ISE	mg/L	APHA4500FC	0.05	1.08	1.09	1.07
Iron (Total)	mg/L	APHA3120B	0.005	0.05	0.008	0.02
Manganese (Total)	mg/L	APHA3120B	0.005	0.009	<0.005	<0.005

General comments: This report must not be reproduced except in full. This report relates only to the items tested as specified herein. Samples analysed between date received and date reported. Accredited for compliance with ISO/IEC 17025 # NATA accreditation does not cover the performance of this service. Tests marked with * are subcontracted. LOR denotes 'Limit of Reporting'

Specific comments:


M Window
Laboratory Analyst
Approved Authoriser