



Certificate Of Analysis

Client: Richmond Valley Council
Address: Locked Bag 10
Casino NSW 2470
Contact: Aidan Macqueen
Sampled by: Gary Mead
Subcontract Laboratory: Envirolab (NATA2901)
Subcontract Reference: 178115

Final report

Report no: 17/1706
Date received: 17/10/2017
Testing commenced: 17/10/2017
Date reported: 2/11/2017
No. of samples: 2
Revision no: 00

Analysis results apply to samples as received.

Raw and Finished Weekly

Sample No.: Sample description: Date sampled:	Unit	Method	LOR	17/1706-1 RVC Finished Water 17/10/2017	17/1706-2 RVC Raw Water 17/10/2017
pH	pH	APHA4500H		7.5	7.3
Electrical Conductivity	µS/cm	APHA2510B	1	410	205
Total Dissolved Solids by calc	mg/L	APHA1030E	2	262	131
Dissolved Oxygen	mg/L	APHA4500OG	0.2	8.6	7.0
Fluoride - ISE	mg/L	APHA4500FC	0.05	1.04	[NA]
Colour (Apparent)	Pt-Co	RWL10.02	2	<2	1,082
Colour (True)	Pt-Co	RWL10.02	2	<2	140
Turbidity	NTU	APHA2130B	0.1	0.11	250
Alkalinity (as CaCO ₃)	mg/L	APHA2320B	20	127	60
Suspended Solids	mg/L	APHA2540D	1	<1	372
Total Organic Carbon*	mg/L	Envirolab	1	3	15
Aluminium (Total)	mg/L	APHA3120B	0.005	0.084	10.2
Aluminium (Dissolved)	mg/L	APHA3120B	0.005	0.078	1.10
Iron (Total)	mg/L	APHA3120B	0.005	<0.005	16.4



Certificate Of Analysis

Client: Richmond Valley Council

Report no: 17/1706

Sample No.: Sample description: Date sampled:	Unit	Method	LOR	17/1706-1 RVC Finished Water 17/10/2017	17/1706-2 RVC Raw Water 17/10/2017
Iron (Dissolved)	mg/L	APHA3120B	0.005	<0.005	0.86
Manganese (Total)	mg/L	APHA3120B	0.005	<0.005	0.059
Manganese (Dissolved)	mg/L	APHA3120B	0.005	<0.005	0.008
Calcium	mg/L	APHA3120B	0.1	26.1	15.1
Magnesium	mg/L	APHA3120B	0.1	16.3	10.9
Hardness as CaCO ₃	mg/L	APHA2340B	1	132	83
Total Coliforms	MPN/100mL	APHA9223B	1	<1	241,960
<i>E.coli</i>	MPN/100mL	APHA9223B	1	<1	10,190
Heterotrophic Plate Count	MPN/mL	APHA9215E	2	<2	50,700

General comments: This report must not be reproduced except in full. This report relates to items tested as specified herein.
Samples tested between date received and date reported. Accredited for compliance with ISO/IEC 17025.
NATA accreditation does not cover the performance of this service. Tests marked with * are subcontracted.
LOR denotes 'Limit of Reporting'

Specific comments:

A. Hawthorne
Laboratory Manager
Approved Authoriser