



## Certificate Of Analysis

**Client:** Richmond Valley Council

**Address:** Locked Bag 10  
Casino NSW 2470

**Contact:** Aidan Macqueen

**Sampled by:** Mia Donnelly

\* **Subcontract Laboratory:** Pathology North

\* **Subcontract Reference:** 326583836

*Sampled in accordance with RWL 2.0 to 2.05*

Final report

RVC Consumer Weekly

**Report no:** 17/1889

**Date received:** 21/11/2017

**Testing commenced:** 21/11/2017

**Date reported:** 24/11/2017

**No. of samples:** 9

**Revision no:** 01

Sample No.: Sample description:  Date sampled:	Unit	Method	LOR	17/1889/1 Casino Showground 21/11/2017	17/1889/2 Casino Walker Street 21/11/2017	17/1889/3 Casino South Res 21/11/2017	17/1889/4 Coraki Memorial Park 21/11/2017	17/1889/5 Woodburn Riverside Park 21/11/2017	17/1889/6 Broadwater Community Centre 21/11/2017	17/1889/7 Rileys Hill Community Centre 21/11/2017	17/1889/8 Evans Head School 21/11/2017
pH - field	pH	APHA4500H	2	7.7	7.5	7.5	7.7	8.1	8.1	8.1	8.1
Chlorine Free - field	mg/L	APHA4500CIG	0.05	0.48	0.56	1.07	0.57	0.79	0.93	0.82	0.75
Chlorine Total - field	mg/L	APHA4500CIG	0.05	0.63	0.72	1.23	0.60	0.85	0.96	0.86	0.81
Temperature - field	Deg. C	APHA2550B	0.1	22.9	24.3	22.9	26.5	23.4	22.2	23.1	23.5
Dissolved Oxygen - field	mg/L	APHA4500OG	1	8.3	8.2	8.3	7.9	8.7	8.9	8.4	8.5
Turbidity - field#	NTU	APHA2130B	0.1	0.20	0.24	0.34	0.16	0.15	0.17	0.23	0.16
Total Coliforms*#	MPN/100mL	PNWI01	1	<1	<1	<1	<1	<1	<1	<1	<1
<i>E.coli</i> *#	MPN/100mL	PNWI02	1	<1	<1	<1	<1	<1	<1	<1	<1
Total Plate Count*#	cfu/mL	PNWMF03	1	10	3	<1	<1	2	1	1	<1



## Certificate Of Analysis

**Client:** Richmond Valley Council

**Report no:** 17/1889

Sample No.: Sample description: Date sampled:	Unit	Method	LOR	17/1889/9 Evans Head High Zone 21/11/2017
pH - field	pH	APHA4500H	2	8.2
Chlorine Free - field	mg/L	APHA4500CIG	0.05	0.23
Chlorine Total - field	mg/L	APHA4500CIG	0.05	0.27
Temperature - field	Deg. C	APHA2550B	0.1	22.3
Dissolved Oxygen - field	mg/L	APHA4500OG	1	8.5
Turbidity - field#	NTU	APHA2130B	0.1	0.17
Total Coliforms*#	MPN/100mL	PNWI01	1	<1
<i>E.coli</i> *#	MPN/100mL	PNWI02	1	<1
Total Plate Count*#	cfu/mL	PNWMF03	1	21

General comments: This report must not be reproduced except in full. This report relates only to items tested as specified herein. Samples analysed between date received and date reported. Accredited for compliance with ISO/IEC 17025. # NATA accreditation does not cover the performance of this service. Tests marked with \* are subcontracted. LOR denotes 'Limit of Reporting'

Specific comments: This is the final report that supersedes the preliminary report issued on the 21.11.17

A. Hawthorne  
Laboratory Manager  
Approved Authoriser