



## Certificate Of Analysis

**Client:** Richmond Valley Council  
**Address:** Locked Bag 10  
Casino NSW 2470  
**Contact:** Aidan Macqueen  
**Sampled by:** Gary Mead  
**Subcontract Laboratory:** Envirolab, UUQ (NATA 11085)  
**Subcontract Reference:** 181146, 17-11270  
*Analysis results apply to samples as received.*

Final report

**Report no:** 17/1928  
**Date received:** 28/11/2017  
**Testing commenced:** 28/11/2017  
**Date reported:** 11/12/2017  
**No. of samples:** 2  
**Revision no:** 00

Raw and Finished Weekly

Sample No.: Sample description:  Date sampled:	Unit	Method	LOR	17/1928-1 RVC Finished Water 28/11/2017	17/1928-2 RVC Raw Water 28/11/2017
Total Toxic Blue Green Algae*	cells/mL	UUQ	10	[NA]	[ND]
pH	pH	APHA4500H		7.1	7.7
Electrical Conductivity	µS/cm	APHA2510B	1	412	280
Total Dissolved Solids by calc	mg/L	APHA1030E	2	264	179
Dissolved Oxygen	mg/L	APHA4500OG	0.2	8.4	8.3
Fluoride - ISE	mg/L	APHA4500FC	0.05	1.10	[NA]
Colour (Apparent)	Pt-Co	RWL10.02	2	<2	110
Colour (True)	Pt-Co	RWL10.02	2	<2	67
Turbidity	NTU	APHA2130B	0.1	0.12	21
Alkalinity (as CaCO <sub>3</sub> )	mg/L	APHA2320B	20	110	103
Suspended Solids	mg/L	APHA2540D	1	2	19
Total Organic Carbon*	mg/L	Envirolab	1	3	6
Aluminium (Total)	mg/L	APHA3120B	0.005	0.075	2.05
Aluminium (Dissolved)	mg/L	APHA3120B	0.005	0.067	0.43



## Certificate Of Analysis

**Client:** Richmond Valley Council

**Report no:** 17/1928

Sample No.: Sample description: Date sampled:	Unit	Method	LOR	17/1928-1 RVC Finished Water 28/11/2017	17/1928-2 RVC Raw Water 28/11/2017
Iron (Total)	mg/L	APHA3120B	0.005	<0.005	1.8
Iron (Dissolved)	mg/L	APHA3120B	0.005	<0.005	0.41
Manganese (Total)	mg/L	APHA3120B	0.005	<0.005	0.070
Manganese (Dissolved)	mg/L	APHA3120B	0.005	<0.005	0.01
Calcium	mg/L	APHA3120B	0.1	18.3	19.5
Magnesium	mg/L	APHA3120B	0.1	11.5	12.5
Hardness as CaCO <sub>3</sub>	mg/L	APHA2340B	1	93	100
Total Coliforms	MPN/100mL	APHA9223B	1	<1	1,354
<i>E.coli</i>	MPN/100mL	APHA9223B	1	<1	38
Heterotrophic Plate Count	MPN/mL	APHA9215E	2	<2	1,860

General comments: This report must not be reproduced except in full. This report relates to items tested as specified herein.  
Samples tested between date received and date reported. Accredited for compliance with ISO/IEC 17025.  
# NATA accreditation does not cover the performance of this service. Tests marked with \* are subcontracted.  
LOR denotes 'Limit of Reporting'

Specific comments:

A. Hawthorne  
Laboratory Manager  
Approved Authoriser