



Certificate Of Analysis

Client: Richmond Valley Council

Address: Locked Bag 10
Casino NSW 2470

Contact: Aidan Macqueen

Sampled by: Mia Donnelly

* **Subcontract Laboratory:** Envirolab (NATA2901)

* **Subcontract Reference:** 183173

Sampled in accordance with RWL 2.0 to 2.05

Final report

RVC Casino Consumer Monthly

Report no: 18/0047

Date received: 9/01/2018

Testing commenced: 9/01/2018

Date reported: 23/01/2018

No. of samples: 3

Revision no: 00

Sample No.: Sample description: Date sampled:	Unit	Method	LOR	18/0047/1 Casino Walker Street 9/01/2018	18/0047/2 Casino North Res 9/01/2018	18/0047/3 Casino Sheppard St 9/01/2018
Fluoride - ISE	mg/L	APHA4500FC	0.05	1.09	1.09	1.12
Colour (True)	Pt-Co	RWL10.02	2	2	<2	2
Ammonia-N	mg/L	RWL 10.06	0.01	<0.01	<0.01	<0.01
Nitrogen - Nitrate-N	mg/L	RWL 10.05	0.05	0.06	0.13	0.06
Nitrogen - Nitrite-N	mg/L	RWL 10.05	0.01	<0.01	<0.01	<0.01
Aluminium (Total)	mg/L	APHA3120B	0.005	0.10	0.13	0.14
Copper (Total)	mg/L	APHA3120B	0.005	0.031	<0.005	0.009
Iron (Total)	mg/L	APHA3120B	0.005	0.02	0.01	0.03
Lead (Total)	mg/L	APHA3120B	0.005	<0.005	<0.005	<0.005
Manganese (Total)	mg/L	APHA3120B	0.005	<0.005	0.005	<0.005
Zinc (Total)	mg/L	APHA3120B	0.005	0.005	<0.005	<0.005
Total Trihalomethanes*	µg/L	Envirolab	1	103	85	87



Certificate Of Analysis

Client: Richmond Valley Council

Report no: 18/0047

General comments: This report must not be reproduced except in full. This report relates only to items tested as specified herein.
Samples analysed between date received and date reported. Accredited for compliance with ISO/IEC 17025.
NATA accreditation does not cover the performance of this service. Tests marked with * are subcontracted.
LOR denotes 'Limit of Reporting'

Specific comments:

A. Hawthorne
Laboratory Manager
Approved Authoriser