



## Certificate Of Analysis

**Client:** Richmond Valley Council  
**Address:** Locked Bag 10  
Casino NSW 2470  
**Contact:** Aidan Macqueen  
**Sampled by:** Mia Donnelly

Final report

**Report no:** 18/0132  
**Date received:** 23/01/2018  
**Testing commenced:** 23/01/2018  
**Date reported:** 29/01/2018  
**No. of samples:** 9  
**Revision no:** 01

\* **Subcontract Laboratory:** Pathology North

\* **Subcontract Reference:** 326739752

RVC Consumer Weekly

Sampled in accordance with RWL 2.0 to 2.05

Sample No.: Sample description:  Date sampled:	Unit	Method	LOR	18/0132/1 Casino Sextonville Rd 23/01/2018	18/0132/2 Casino Walker Street 23/01/2018	18/0132/3 Coraki Memorial Park 23/01/2018	18/0132/4 Woodburn Riverside Park 23/01/2018	18/0132/5 Broadwater Community Centre 23/01/2018	18/0132/6 Rileys Hill Community Centre 23/01/2018	18/0132/7 Evans Head School 23/01/2018	18/0132/8 Evans Head High Zone 23/01/2018
pH - field	pH	APHA4500H	2	7.4	7.5	7.6	8.1	8.1	8.1	8.0	8.1
Chlorine Free - field	mg/L	APHA4500CIG	0.05	0.98	0.77	0.54	0.78	0.87	0.77	0.60	0.17
Chlorine Total - field	mg/L	APHA4500CIG	0.05	1.16	0.96	0.61	0.87	0.95	0.88	0.69	0.23
Temperature - field	Deg. C	APHA2550B	0.1	31.1	30.3	32.1	27.8	25.6	28.2	27.5	25.8
Dissolved Oxygen - field	mg/L	APHA4500OG	1	7.1	7.3	7.2	7.3	8.1	7.8	7.5	7.9
Turbidity - field#	NTU	APHA2130B	0.1	0.49	0.29	0.32	0.17	0.21	0.21	0.15	0.19
Total Coliforms*#	MPN/100mL	PNWI01	1	<1	<1	<1	<1	<1	<1	<1	<1
<i>E.coli</i> *#	MPN/100mL	PNWI02	1	<1	<1	<1	<1	<1	<1	<1	<1
Total Plate Count*#	cfu/mL	PNWMF03	1	<1	<1	<1	<1	<1	<1	<1	40



## Certificate Of Analysis

**Client:** Richmond Valley Council

**Report no:** 18/0132

Sample No.: Sample description: Date sampled:	Unit	Method	LOR	18/0132/9 Siversands Caravan Park 23/01/2018
pH - field	pH	APHA4500H	2	8.1
Chlorine Free - field	mg/L	APHA4500CIG	0.05	0.65
Chlorine Total - field	mg/L	APHA4500CIG	0.05	0.72
Temperature - field	Deg. C	APHA2550B	0.1	25.5
Dissolved Oxygen - field	mg/L	APHA4500OG	1	7.9
Turbidity - field#	NTU	APHA2130B	0.1	0.32
Total Coliforms*#	MPN/100mL	PNWI01	1	<1
<i>E.coli</i> *#	MPN/100mL	PNWI02	1	<1
Total Plate Count*#	cfu/mL	PNWMF03	1	<1

General comments: This report must not be reproduced except in full. This report relates only to items tested as specified herein. Samples analysed between date received and date reported. Accredited for compliance with ISO/IEC 17025. # NATA accreditation does not cover the performance of this service. Tests marked with \* are subcontracted. LOR denotes 'Limit of Reporting'

Specific comments: This is the final report that supersedes the preliminary report issued on the 23.01.18

M Window  
Laboratory Analyst  
Approved Authoriser