



Certificate Of Analysis

Client: Richmond Valley Council
Address: Locked Bag 10
Casino NSW 2470
Contact: Aidan Macqueen
Sampled by: Gary Mead
Subcontract Laboratory: Envirolab (NATA2901)
Subcontract Reference: 184277

Final report

Report no: 18/0131
Date received: 23/01/2018
Testing commenced: 23/01/2018
Date reported: 12/02/2018
No. of samples: 2
Revision no: 01

Analysis results apply to samples as received.

Raw and Finished Weekly

Sample No.: Sample description:	Unit	Method	LOR	18/0131-1 RVC Finished Water 23/01/2018 11:30	18/0131-2 RVC Raw Water 23/01/2018 11:00
Date sampled:					
Time sampled:					
pH	pH	APHA4500H		7.3	7.8
Electrical Conductivity	µS/cm	APHA2510B	1	445	319
Total Dissolved Solids by calc	mg/L	APHA1030E	2	285	204
Dissolved Oxygen	mg/L	APHA4500OG	0.2	8.1	8.2
Fluoride - ISE	mg/L	APHA4500FC	0.05	1.06	[NA]
Colour (Apparent)	Pt-Co	RWL10.02	2	<2	60
Colour (True)	Pt-Co	RWL10.02	2	<2	18
Turbidity	NTU	APHA2130B	0.1	<0.10	8.2
Alkalinity (as CaCO ₃)	mg/L	APHA2320B	20	113	130
Suspended Solids	mg/L	APHA2540D	1	2	11
Total Organic Carbon*	mg/L	Envirolab	1	2	5
Aluminium (Total)	mg/L	APHA3120B	0.005	0.070	0.44
Aluminium (Dissolved)	mg/L	APHA3120B	0.005	0.069	0.031



Certificate Of Analysis

Client: Richmond Valley Council

Report no: 18/0131

Sample No.: Sample description:	Unit	Method	LOR	18/0131-1 RVC Finished Water 23/01/2018 11:30	18/0131-2 RVC Raw Water 23/01/2018 11:00
Date sampled:					
Time sampled:					
Iron (Total)	mg/L	APHA3120B	0.005	<0.005	0.48
Iron (Dissolved)	mg/L	APHA3120B	0.005	<0.005	0.020
Manganese (Total)	mg/L	APHA3120B	0.005	<0.005	0.099
Manganese (Dissolved)	mg/L	APHA3120B	0.005	<0.005	0.009
Calcium	mg/L	APHA3120B	0.1	22.4	23.5
Magnesium	mg/L	APHA3120B	0.1	14.0	14.9
Hardness as CaCO ₃	mg/L	APHA2340B	1	114	120
Total Coliforms	MPN/100mL	APHA9223B	1	<1	1,678
<i>E.coli</i>	MPN/100mL	APHA9223B	1	<1	57
Heterotrophic Plate Count	MPN/mL	APHA9215E	2	<2	1,860

General comments: This report must not be reproduced except in full. This report relates to items tested as specified herein.
Samples tested between date received and date reported. Accredited for compliance with ISO/IEC 17025.
NATA accreditation does not cover the performance of this service. Tests marked with * are subcontracted.
LOR denotes 'Limit of Reporting'

Specific comments:

V. Barnett
Laboratory Analyst
Approved Authoriser