



Certificate Of Analysis

Client: Richmond Valley Council
Address: Locked Bag 10
Casino NSW 2470
Contact: Aidan Macqueen
Sampled by: Gary Mead
Subcontract Laboratory: Envirolab (NATA2901)
Subcontract Reference: 186426

Final report

Report no: 18/0291-A
Date received: 20/02/2018
Testing commenced: 20/02/2018
Date reported: 12/03/2018
No. of samples: 2
Revision no: 00

Analysis results apply to samples as received.

Raw and Finished Weekly

Sample No.: Sample description:	Unit	Method	LOR	18/0291-A-1 RVC Finished Water 20/02/2018 11:30	18/0291-A-2 RVC Raw Water 20/02/2018 11:00
pH	pH	APHA4500H		7.2	7.4
Electrical Conductivity	µS/cm	APHA2510B	1	482	271
Total Dissolved Solids by calc	mg/L	APHA1030E	2	308	173
Dissolved Oxygen	mg/L	APHA4500OG	0.2	8.0	5.8
Fluoride - ISE	mg/L	APHA4500FC	0.05	<u>6.1</u>	[NA]
Colour (Apparent)	Pt-Co	RWL10.02	2	<2	67
Colour (True)	Pt-Co	RWL10.02	2	<2	15
Turbidity	NTU	APHA2130B	0.1	0.10	8.5
Alkalinity (as CaCO ₃)	mg/L	APHA2320B	20	112	106
Suspended Solids	mg/L	APHA2540D	1	1	11
Total Organic Carbon*	mg/L	Envirolab	1	2	3
Aluminium (Total)	mg/L	APHA3120B	0.005	0.069	0.48
Aluminium (Dissolved)	mg/L	APHA3120B	0.005	0.069	0.027



Certificate Of Analysis

Client: Richmond Valley Council

Report no: 18/0291-A

Sample No.: Sample description: Date sampled: Time sampled:	Unit	Method	LOR	18/0291-A-1 RVC Finished Water 20/02/2018 11:30	18/0291-A-2 RVC Raw Water 20/02/2018 11:00
Iron (Total)	mg/L	APHA3120B	0.005	<0.005	0.63
Iron (Dissolved)	mg/L	APHA3120B	0.005	<0.005	0.028
Manganese (Total)	mg/L	APHA3120B	0.005	<0.005	0.32
Manganese (Dissolved)	mg/L	APHA3120B	0.005	<0.005	0.14
Calcium	mg/L	APHA3120B	0.1	19.4	20.5
Magnesium	mg/L	APHA3120B	0.1	12.1	12.7
Hardness as CaCO ₃	mg/L	APHA2340B	1	98	103
Total Coliforms	MPN/100mL	APHA9223B	1	<1	10,950
<i>E.coli</i>	MPN/100mL	APHA9223B	1	<1	31
Heterotrophic Plate Count	MPN/mL	APHA9215E	2	<2	3,220

General comments: This report must not be reproduced except in full. This report relates to items tested as specified herein.
Samples tested between date received and date reported. Accredited for compliance with ISO/IEC 17025.
NATA accreditation does not cover the performance of this service. Tests marked with * are subcontracted.
LOR denotes 'Limit of Reporting'

Specific comments: This is the final report that supersedes the preliminary report issued on the 28.02.18
Please see report 18/0291-B for results of the repeat fluoride on Finished.

M Window
Laboratory Analyst
Approved Authoriser