



## Certificate Of Analysis

**Client:** Richmond Valley Council  
**Address:** Locked Bag 10  
Casino NSW 2470  
**Contact:** Aidan Macqueen  
**Sampled by:** Malcolm Window

Final report

**Report no:** 18/0587  
**Date received:** 10/04/2018  
**Testing commenced:** 10/04/2018  
**Date reported:** 13/04/2018  
**No. of samples:** 10  
**Revision no:** 01

\* **Subcontract Laboratory:** Pathology North

\* **Subcontract Reference:** 334975005

RVC Consumer Weekly

Sampled in accordance with RWL 2.0 to 2.05

Sample No.: Sample description:	Unit	Method	LOR	18/0587/1 Casino Sheppard St	18/0587/2 Casino North Res	18/0587/3 Casino Walker Street	18/0587/4 Coraki Memorial Park	18/0587/5 Box Ridge Community	18/0587/6 Woodburn Riverside Park	18/0587/7 Broadwater Community Centre	18/0587/8 Rileys Hill Community Centre
Date sampled: Time sampled:				10/04/2018 13:00	10/04/2018 13:15	10/04/2018 12:50	10/04/2018 12:00	10/04/2018 12:15	10/04/2018 8:10	10/04/2018 9:05	10/04/2018 8:55
pH - field	pH	APHA4500H	2	7.7	7.6	7.7	7.8	7.9	8.1	8.0	8.1
Chlorine Free - field	mg/L	APHA4500CIG	0.05	1.00	1.31	0.87	0.30	0.36	0.55	0.70	0.51
Chlorine Total - field	mg/L	APHA4500CIG	0.05	1.20	1.58	1.14	0.48	0.53	0.88	0.93	0.86
Temperature - field	Deg. C	APHA2550B	0.1	27.3	24.5	28.1	26.3	27.3	25.8	23.8	23.0
Dissolved Oxygen - field	mg/L	APHA4500OG	1	7.7	8.1	7.8	7.7	7.7	8.1	8.4	8.5
Turbidity - field#	NTU	APHA2130B	0.1	0.52	0.68	0.72	0.33	0.44	0.26	0.51	0.30
Total Coliforms*#	MPN/100mL	PNWI01	1	<1	<1	<1	<1	<1	<1	<1	<1
<i>E.coli</i> *#	MPN/100mL	PNWI02	1	<1	<1	<1	<1	<1	<1	<1	<1
Total Plate Count*#	cfu/mL	PNWMF03	1	<1	<1	<1	<1	<1	<1	<1	10



## Certificate Of Analysis


**Client:** Richmond Valley Council

**Report no:** 18/0587

Sample No.: Sample description:  Date sampled: Time sampled:	Unit	Method	LOR	18/0587/9 Evans Head School 10/04/2018 9:40	18/0587/10 Evans Head High Zone 10/04/2018 9:50
pH - field	pH	APHA4500H	2	8.1	8.3
Chlorine Free - field	mg/L	APHA4500CIG	0.05	0.57	0.39
Chlorine Total - field	mg/L	APHA4500CIG	0.05	0.84	0.54
Temperature - field	Deg.C	APHA2550B	0.1	25.8	25.1
Dissolved Oxygen - field	mg/L	APHA4500OG	1	7.8	7.9
Turbidity - field#	NTU	APHA2130B	0.1	0.40	0.38
Total Coliforms*#	MPN/100mL	PNWI01	1	<1	<1
<i>E.coli</i> *#	MPN/100mL	PNWI02	1	<1	<1
Total Plate Count*#	cfu/mL	PNWMF03	1	<1	50

**General comments:** This report must not be reproduced except in full. This report relates only to items tested as specified herein. Samples analysed between date received and date reported. Accredited for compliance with ISO/IEC 17025.  
# NATA accreditation does not cover the performance of this service. Tests marked with \* are subcontracted.  
LOR denotes 'Limit of Reporting'

**Specific comments:** This is the final report that supersedes the preliminary report issued on the 11/04/18.



A. Hawthorne  
Laboratory Manager  
Approved Authoriser