



## Certificate Of Analysis

**Client:** Richmond Valley Council  
**Address:** Locked Bag 10  
Casino NSW 2470  
**Contact:** Aidan Macqueen  
**Sampled by:** Michael Macrae  
**Subcontract Laboratory:** UUQ (NATA 11085) / Envirolab (NATA 2901)  
**Subcontract Reference:** 18-03053-B / 188869  
*Analysis results apply to samples as received.*

Final report

**Report no:** 18/0559  
**Date received:** 3/04/2018  
**Testing commenced:** 3/04/2018  
**Date reported:** 13/04/2018  
**No. of samples:** 2  
**Revision no:** 00

Raw and Finished Mthly

Sample No.: Sample description:	Unit	Method	LOR	18/0559-1 RVC Finished Water 3/04/2018 11:30	18/0559-2 RVC Raw Water 3/04/2018 11:50
pH	pH	APHA4500H		7.7	7.8
Electrical Conductivity	µS/cm	APHA2510B	1	395	218
Total Dissolved Solids by calc	mg/L	APHA1030E	2	253	140
Dissolved Oxygen	mg/L	APHA4500OG	0.2	8.6	[NA]
Fluoride - ISE	mg/L	APHA4500FC	0.05	0.98	[NA]
Colour (Apparent)	Pt-Co	RWL10.02	2	<2	130
Colour (True)	Pt-Co	RWL10.02	2	<2	39
Turbidity	NTU	APHA2130B	0.1	0.17	27
Aluminium (Total)	mg/L	APHA3120B	0.005	0.10	2.19
Aluminium (Dissolved)	mg/L	APHA3120B	0.005	0.073	0.25
Iron (Total)	mg/L	APHA3120B	0.005	<0.005	2.4
Iron (Dissolved)	mg/L	APHA3120B	0.005	<0.005	0.36
Manganese (Total)	mg/L	APHA3120B	0.005	<0.005	0.058



## Certificate Of Analysis

**Client:** Richmond Valley Council

**Report no:** 18/0559

Sample No.: Sample description:	Unit	Method	LOR	18/0559-1 RVC Finished Water 3/04/2018 11:30	18/0559-2 RVC Raw Water 3/04/2018 11:50
Manganese (Dissolved)	mg/L	APHA3120B	0.005	<0.005	<0.005
Alkalinity (as CaCO <sub>3</sub> )	mg/L	APHA2320B	20	87	82
Suspended Solids	mg/L	APHA2540D	1	<1	20
Total Organic Carbon*	mg/L	Envirolab	1	2	5
Phosphorus - Total	mg/L	RWL 10.07	0.05	<0.05	0.17
Nitrogen - Nitrite-N	mg/L	RWL 10.05	0.01	<0.01	0.02
Nitrogen - Nitrate-N	mg/L	RWL 10.05	0.05	0.13	0.20
Dissolved Organic Carbon*	mg/L	Envirolab	1	2	4
Total Trihalomethanes*	µg/L	Envirolab	1	48	[NA]
2-methylisoborneol*	ng/L	UUQ	2	[NA]	<2
Geosmin*	ng/L	UUQ	2	[NA]	<2
Calcium	mg/L	APHA3120B	0.1	16.0	15.8
Magnesium	mg/L	APHA3120B	0.1	9.8	10
Hardness as CaCO <sub>3</sub>	mg/L	APHA2340B	1	80	81
Total Coliforms	MPN/100mL	APHA9223B	1	<1	3,028
<i>E. coli</i>	MPN/100mL	APHA9223B	1	<1	142
Heterotrophic Plate Count	MPN/mL	APHA9215E	2	<2	7,175



## Certificate Of Analysis

**Client:** Richmond Valley Council

**Report no:** 18/0559

General comments: This report must not be reproduced except in full. This report relates to items tested as specified herein.  
Samples tested between date received and date reported. Accredited for compliance with ISO/IEC 17025.  
# NATA accreditation does not cover the performance of this service. Tests marked with \* are subcontracted.  
LOR denotes 'Limit of Reporting'

Specific comments:

A. Hawthorne  
Laboratory Manager  
Approved Authoriser