



Certificate Of Analysis

Client: Richmond Valley Council

Address: Locked Bag 10
Casino NSW 2470

Contact: Aidan Macqueen

Sampled by: Malcolm Window

* **Subcontract Laboratory:** Envirolab (NATA2901)

* **Subcontract Reference:** 189375

Sampled in accordance with RWL 2.0 to 2.05

Final report

RVC Casino Consumer Monthly

Report no: 18/0588

Date received: 10/04/2018

Testing commenced: 10/04/2018

Date reported: 24/04/2018

No. of samples: 3

Revision no: 00

Sample No.: Sample description: Date sampled: Time sampled:	Unit	Method	LOR	18/0588/1 Casino Walker Street	18/0588/2 Casino North Res	18/0588/3 Casino Sheppard St
Fluoride - ISE	mg/L	APHA4500FC	0.05	0.99	0.99	0.999
Colour (True)	Pt-Co	RWL10.02	2	<2	<2	<2
Ammonia-N	mg/L	RWL 10.06	0.01	<0.01	<0.01	<0.01
Nitrogen - Nitrate-N	mg/L	RWL 10.05	0.05	0.05	0.05	0.05
Nitrogen - Nitrite-N	mg/L	RWL 10.05	0.01	<0.01	<0.01	<0.01
Aluminium (Total)	mg/L	APHA3120B	0.005	0.16	0.46	0.16
Copper (Total)	mg/L	APHA3120B	0.005	0.13	0.007	0.013
Iron (Total)	mg/L	APHA3120B	0.005	0.02	0.02	0.005
Lead (Total)	mg/L	APHA3120B	0.005	0.006	<0.005	<0.005
Manganese (Total)	mg/L	APHA3120B	0.005	<0.005	<0.005	<0.005
Zinc (Total)	mg/L	APHA3120B	0.005	0.041	<0.005	<0.005
Total Trihalomethanes*	µg/L	Envirolab	1	48	47	67



Certificate Of Analysis

Client: Richmond Valley Council

Report no: 18/0588

General comments: This report must not be reproduced except in full. This report relates only to items tested as specified herein.
Samples analysed between date received and date reported. Accredited for compliance with ISO/IEC 17025.
NATA accreditation does not cover the performance of this service. Tests marked with * are subcontracted.
LOR denotes 'Limit of Reporting'

Specific comments:

V. Barnett
Laboratory Analyst
Approved Authoriser