



## Certificate Of Analysis

**Client:** Richmond Valley Council  
**Address:** Locked Bag 10  
Casino NSW 2470  
**Contact:** Aidan Macqueen  
**Sampled by:** Mia

Final report

**Report no:** 18/1178 00  
**Date received:** 31/07/2018  
**Testing commenced:** 31/07/2018  
**Date reported:** 3/08/2018  
**No. of samples:** 3


Sampled in accordance with RWL 2.0 to 2.05

Weekly Fluoride

| Sample No.:         | Unit | Method     | LOR   | 18/1178/1            | 18/1178/2         | 18/1178/3        |
|---------------------|------|------------|-------|----------------------|-------------------|------------------|
| Sample description: |      |            |       | Casino Walker Street | Casino Showground | Casino South Res |
| Date sampled:       |      |            |       | 31/07/2018           | 31/07/2018        | 31/07/2018       |
| Time sampled:       |      |            |       | 12:45                | 12:30             | 12:20            |
| Fluoride - ISE      | mg/L | APHA4500FC | 0.05  | 1.08                 | 1.06              | 1.07             |
| Iron (Total)        | mg/L | APHA3120B  | 0.005 | 0.008                | 0.005             | 0.006            |
| Manganese (Total)   | mg/L | APHA3120B  | 0.005 | <0.005               | <0.005            | 0.005            |

General comments: This report must not be reproduced except in full. This report relates only to the items tested as specified herein. Samples analysed between date received and date reported. Accredited for compliance with ISO/IEC 17025 # NATA accreditation does not cover the performance of this service. Tests marked with \* are subcontracted. LOR denotes 'Limit of Reporting'

Specific comments:

  
M Window  
Laboratory Analyst  
Approved Authoriser