



## Certificate Of Analysis

**Client:** Richmond Valley Council  
**Address:** Locked Bag 10  
Casino NSW 2470  
**Contact:** Aidan Macqueen  
**Sampled by:** Gary Mead  
**Subcontract Laboratory:** Envirolab  
**Subcontract Reference:** 197558

Final report

**Report no:** 18/1172  
**Date received:** 31/07/2018  
**Testing commenced:** 31/07/2018  
**Date reported:** 14/08/2018  
**No. of samples:** 2  
**Revision no:** 00

*Analysis results apply to samples as received.*

Raw and Finished Weekly

Sample No.: Sample description:	Unit	Method	LOR	18/1172-1 RVC Finished Water 31/07/2018 11:30	18/1172-2 RVC Raw Water 31/07/2018 11:00
Date sampled:					
Time sampled:					
pH	pH	APHA4500H		7.6	8.0
Electrical Conductivity	µS/cm	APHA2510B	1	361	320
Total Dissolved Solids by calc	mg/L	APHA1030E	2	231	205
Dissolved Oxygen	mg/L	APHA4500OG	0.2	9.9	9.5
Fluoride - ISE	mg/L	APHA4500FC	0.05	1.06	[NA]
Colour (Apparent)	Pt-Co	RWL10.02	2	<2	27
Colour (True)	Pt-Co	RWL10.02	2	<2	8
Turbidity	NTU	APHA2130B	0.1	0.16	4.1
Alkalinity (as CaCO <sub>3</sub> )	mg/L	APHA2320B	20	121	123
Suspended Solids	mg/L	APHA2540D	1	<1	5
Total Organic Carbon*	mg/L	Envirolab	1	2	3
Aluminium (Total)	mg/L	APHA3120B	0.005	0.12	0.19
Aluminium (Dissolved)	mg/L	APHA3120B	0.005	0.086	0.007



## Certificate Of Analysis

**Client:** Richmond Valley Council

**Report no:** 18/1172

Sample No.: Sample description:	Unit	Method	LOR	18/1172-1 RVC Finished Water 31/07/2018 11:30	18/1172-2 RVC Raw Water 31/07/2018 11:00
Date sampled:					
Time sampled:					
Iron (Total)	mg/L	APHA3120B	0.005	<0.005	0.26
Iron (Dissolved)	mg/L	APHA3120B	0.005	<0.005	0.015
Manganese (Total)	mg/L	APHA3120B	0.005	<0.005	0.035
Manganese (Dissolved)	mg/L	APHA3120B	0.005	<0.005	<0.005
Calcium	mg/L	APHA3120B	0.1	23.1	23.4
Magnesium	mg/L	APHA3120B	0.1	14.7	14.8
Hardness as CaCO <sub>3</sub>	mg/L	APHA2340B	1	118	119
Total Coliforms	MPN/100mL	APHA9223B	1	<1	345
<i>E.coli</i>	MPN/100mL	APHA9223B	1	<1	27
Heterotrophic Plate Count	MPN/mL	APHA9215E	2	<2	141

General comments: This report must not be reproduced except in full. This report relates to items tested as specified herein.  
Samples tested between date received and date reported. Accredited for compliance with ISO/IEC 17025.  
# NATA accreditation does not cover the performance of this service. Tests marked with \* are subcontracted.  
LOR denotes 'Limit of Reporting'

Specific comments:

A. Hawthorne  
Laboratory Manager  
Approved Authoriser