



Certificate Of Analysis

Client: Richmond Valley Council
Address: Locked Bag 10
Casino NSW 2470
Contact: Aidan Macqueen
Sampled by: Mia Donnelly

Final report

Report no: 18/1383
Date received: 11/09/2018
Testing commenced: 11/09/2018
Date reported: 21/09/2018
No. of samples: 3
Revision no: 00

* **Subcontract Laboratory:** Envirolab (NATA2901)

* **Subcontract Reference:** 200779

RVC Casino Consumer Monthly

Sampled in accordance with RWL 2.0 to 2.05

Sample No.: Sample description:	Unit	Method	LOR	18/1383/1 Casino Walker Street 11/09/2018	18/1383/2 Casino North Res 11/09/2018	18/1383/3 Casino Sheppard St 11/09/2018
Date sampled: Time sampled:						
Fluoride - ISE	mg/L	APHA4500FC	0.05	1.03	1.03	1.05
Colour (True)	Pt-Co	RWL10.02	2	<2	<2	<2
Ammonia-N	mg/L	RWL 10.06	0.01	<0.01	<0.01	<0.01
Nitrogen - Nitrate-N	mg/L	RWL 10.05	0.05	<0.05	<0.05	<0.05
Nitrogen - Nitrite-N	mg/L	RWL 10.05	0.01	<0.01	<0.01	<0.01
Aluminium (Total)	mg/L	APHA3120B	0.005	0.098	0.16	0.17
Copper (Total)	mg/L	APHA3120B	0.005	0.018	0.009	0.018
Iron (Total)	mg/L	APHA3120B	0.005	0.005	<0.005	0.02
Lead (Total)	mg/L	APHA3120B	0.005	<0.005	<0.005	<0.005
Manganese (Total)	mg/L	APHA3120B	0.005	<0.005	<0.005	<0.005
Zinc (Total)	mg/L	APHA3120B	0.005	<0.005	0.005	0.012
Total Trihalomethanes*	µg/L	Envirolab	1	47	40	47



Certificate Of Analysis

Client: Richmond Valley Council

Report no: 18/1383

General comments: This report must not be reproduced except in full. This report relates only to items tested as specified herein. Samples analysed between date received and date reported. Accredited for compliance with ISO/IEC 17025. # NATA accreditation does not cover the performance of this service. Tests marked with * are subcontracted. LOR denotes 'Limit of Reporting'

Specific comments:

A. Hawthorne
Laboratory Manager
Approved Authoriser