Richmond Water Laboratories

Environmental Analysis - Water Sampling - Data Management



Certificate Of Analysis

Final report

| Client: | Richmond Valley Council | | | | |
|--|-------------------------|--|--|--|--|
| Address: | Locked Bag 10 | | | | |
| | Casino NSW 2470 | | | | |
| Contact: | Aidan Macqueen | | | | |
| Sampled by: | Gary Mead | | | | |
| Subcontract Laboratory: Envirolab (NATA 2901) | | | | | |
| Subcontract Reference: 201207 | | | | | |
| Analysis results apply to samples as received. | | | | | |

 Report no:
 18/1422

 Date received:
 18/09/2018

 Testing commenced:
 18/09/2018

 Date reported:
 27/09/2018

 No. of samples:
 2

 Revision no:
 00

| Sample No.: Sample description: Date sampled: Time sampled: | Unit | Method | LOR | 18/1422-1 RVC Finished Water 18/09/2018 11:30 | 18/1422-2 RVC Raw Water 18/09/2018 11:00 |
|--|-------|------------|-------|--|--|
| рН | pН | APHA4500H | | 7.3 | 7.7 |
| Electrical Conductivity | μS/cm | APHA2510B | 1 | 371 | 337 |
| Total Dissolved Solids by calc | mg/L | APHA1030E | 2 | 237 | 216 |
| Dissolved Oxygen | mg/L | APHA4500OG | 0.2 | 8.8 | 8.4 |
| Fluoride - ISE | mg/L | APHA4500FC | 0.05 | 1.00 | [NA] |
| Colour (Apparent) | Pt-Co | RWL10.02 | 2 | ~2 | 8 |
| Colour (True) | Pt-Co | RWL10.02 | 2 | ~2 | 28 |
| Turbidity | NTU | APHA2130B | 0.1 | <0.10 | 4.6 |
| Alkalinity (as CaCO3) | mg/L | APHA2320B | 20 | 113 | 126 |
| Suspended Solids | mg/L | APHA2540D | 1 | 1 | 8 |
| Total Organic Carbon* | mg/L | Envirolab | 1 | 2 | 3 |
| Aluminium (Total) | mg/L | APHA3120B | 0.005 | 0.11 | 0.24 |
| Aluminium (Dissolved) | mg/L | APHA3120B | 0.005 | 0.087 | 0.028 |

Raw and Finished Weekly

Richmond Water Laboratories

Certificate Of Analysis

Environmental Analysis - Water Sampling - Data Management

NOC 14914

Report no:

18/1422

Sample No.: Unit Method LOR 18/1422-1 18/1422-2 **RVC** Raw Sample description: RVC Finished Water Water Date sampled: 18/09/2018 18/09/2018 Time sampled: 11:30 11:00 Iron (Total) APHA3120B 0.005 < 0.005 0.27 mg/L Iron (Dissolved) APHA3120B 0.005 < 0.005 0.014 mg/L APHA3120B Manganese (Total) mg/L 0.005 < 0.005 0.048 Manganese (Dissolved) APHA3120B 0.005 < 0.005 0.008 mg/L Calcium APHA3120B 0.1 23.8 24.8 mg/L APHA3120B 15.6 Magnesium mg/L 0.1 16.1 Hardness as CaCO3 APHA2340B 124 128 mg/L 1 **Total Coliforms** MPN/100mL APHA9223B 1 <1 687 MPN/100mL APHA9223B 1 12 E.coli <1 Heterotrophic Plate Count MPN/mL APHA9215E 2 <2 77

Richmond Valley Council

General comments:

Client:

This report must not be reproduced except in full. This report relates to items tested as specified herein. Samples tested between date received and date reported. Accredited for compliance with ISO/IEC 17025. # NATA accreditation does not cover the performance of this service. Tests marked with * are subcontracted. LOR denotes 'Limit of Reporting'

Specific comments: