



Certificate Of Analysis

Client: Richmond Valley Council
Address: Locked Bag 10
Casino NSW 2470
Contact: Aidan Macqueen
Sampled by: Michael MacRae
Subcontract Laboratory: UUQ (NATA 11085)
Subcontract Reference: 18-08936
Analysis results apply to samples as received.

Final report

Report no: 18/1537
Date received: 9/10/2018
Testing commenced: 9/10/2018
Date reported: 22/10/2018
No. of samples: 2
Revision no: 00

Raw and Finished Weekly

Sample No.: Sample description: Date sampled: Time sampled:	Unit	Method	LOR	18/1537-1 RVC Finished Water 9/10/2018	18/1537-2 RVC Raw Water 9/10/2018
pH	pH	APHA4500H		7.3	7.6
Electrical Conductivity	µS/cm	APHA2510B	1	357	324
Total Dissolved Solids by calc	mg/L	APHA1030E	2	228	207
Dissolved Oxygen	mg/L	APHA4500OG	0.2	8.8	7.9
Fluoride - ISE	mg/L	APHA4500FC	0.05	1.02	[NA]
Colour (Apparent)	Pt-Co	RWL10.02	2	<2	31
Colour (True)	Pt-Co	RWL10.02	2	<2	10
Turbidity	NTU	APHA2130B	0.1	<0.10	4.5
Alkalinity (as CaCO ₃)	mg/L	APHA2320B	20	104	124
Suspended Solids	mg/L	APHA2540D	1	1	8
Total Organic Carbon*	mg/L	UUQ	1	3	5
Aluminium (Total)	mg/L	APHA3120B	0.005	0.092	0.26
Aluminium (Dissolved)	mg/L	APHA3120B	0.005	0.085	0.024



Certificate Of Analysis

Client: Richmond Valley Council

Report no: 18/1537

Sample No.: Sample description: Date sampled: Time sampled:	Unit	Method	LOR	18/1537-1 RVC Finished Water 9/10/2018	18/1537-2 RVC Raw Water 9/10/2018
Iron (Total)	mg/L	APHA3120B	0.005	<0.005	0.26
Iron (Dissolved)	mg/L	APHA3120B	0.005	<0.005	0.012
Manganese (Total)	mg/L	APHA3120B	0.005	<0.005	0.074
Manganese (Dissolved)	mg/L	APHA3120B	0.005	<0.005	<0.005
Calcium	mg/L	APHA3120B	0.1	22.4	23.1
Magnesium	mg/L	APHA3120B	0.1	15.0	15.1
Hardness as CaCO ₃	mg/L	APHA2340B	1	118	120
Total Coliforms	MPN/100mL	APHA9223B	1	<1	649
<i>E.coli</i>	MPN/100mL	APHA9223B	1	<1	23
Heterotrophic Plate Count	MPN/mL	APHA9215E	2	<2	510

General comments: This report must not be reproduced except in full. This report relates to items tested as specified herein.
Samples tested between date received and date reported. Accredited for compliance with ISO/IEC 17025.
NATA accreditation does not cover the performance of this service. Tests marked with * are subcontracted.
LOR denotes 'Limit of Reporting'

Specific comments:

M Window
Laboratory Analyst
Approved Authoriser