



Certificate Of Analysis

Client: Richmond Valley Council
Address: Locked Bag 10
Casino NSW 2470
Contact: Aidan Macqueen
Sampled by: Mia

Final report

Report no: 18/1533
Date received: 9/10/2018
Testing commenced: 9/10/2018
Date reported: 23/10/2018
No. of samples: 3
Revision no: 00

* **Subcontract Laboratory:** Envirolab (NATA 2901)

* **Subcontract Reference:** 202904

RVC Casino Consumer Monthly

Sampled in accordance with RWL 2.0 to 2.05

Sample No.: Sample description: Date sampled: Time sampled:	Unit	Method	LOR	18/1533/1 Casino Bruton St 9/10/2018	18/1533/2 Casino Council Depot 9/10/2018	18/1533/3 Casino Walker Street 9/10/2018
Colour (True)	Pt-Co	RWL10.02	2	<2	<2	<2
Ammonia-N	mg/L	RWL 10.06	0.01	<0.01	<0.01	<0.01
Nitrogen - Nitrate-N	mg/L	RWL 10.05	0.05	<0.05	<0.05	<0.05
Nitrogen - Nitrite-N	mg/L	RWL 10.05	0.01	<0.01	<0.01	<0.01
Aluminium (Total)	mg/L	APHA3120B	0.005	0.15	0.21	0.10
Copper (Total)	mg/L	APHA3120B	0.005	0.029	0.021	0.035
Iron (Total)	mg/L	APHA3120B	0.005	0.008	0.01	0.01
Lead (Total)	mg/L	APHA3120B	0.005	<0.005	<0.005	<0.005
Manganese (Total)	mg/L	APHA3120B	0.005	0.007	0.009	<0.005
Zinc (Total)	mg/L	APHA3120B	0.005	0.017	<0.005	0.005
Total Trihalomethanes*	µg/L	Envirolab	1	71	69	72
Fluoride - ISE	mg/L	APHA4500FC	0.05	0.94	0.92	0.97



Certificate Of Analysis

Client: Richmond Valley Council

Report no: 18/1533

General comments: This report must not be reproduced except in full. This report relates only to items tested as specified herein.
Samples analysed between date received and date reported. Accredited for compliance with ISO/IEC 17025.
NATA accreditation does not cover the performance of this service. Tests marked with * are subcontracted.
LOR denotes 'Limit of Reporting'

Specific comments:

V. Barnett
Laboratory Analyst
Approved Authoriser