



Certificate Of Analysis

Client: Richmond Valley Council
Address: Locked Bag 10
Casino NSW 2470
Contact: Aidan Macqueen
Sampled by: Mia Donnelly

Final report

Report no: 18/1619
Date received: 23/10/2018
Testing commenced: 23/10/2018
Date reported: 30/10/2018
No. of samples: 9
Revision no: 01

* **Subcontract Laboratory:** Pathology North

* **Subcontract Reference:** 326859535

RVC Consumer Weekly

Sampled in accordance with RWL 2.0 to 2.05

Sample No.: Sample description:	Unit	Method	LOR	18/1619/1 Casino Showground	18/1619/2 Casino Walker Street	18/1619/3 Casino South Res	18/1619/4 Coraki Memorial Park	18/1619/5 Woodburn Riverside Park	18/1619/6 Broadwater Community Centre	18/1619/7 Rileys Hill Community Centre	18/1619/8 Evans Head School
Date sampled: Time sampled:				23/10/2018 12:35	23/10/2018 12:50	23/10/2018 12:20	23/10/2018 11:50	23/10/2018 07:00	23/10/2018 10:10	23/10/2018 07:40	23/10/2018 09:35
pH - field	pH	APHA4500H	2	7.7	7.4	7.4	7.6	8.1	8.1	8.0	8.1
Chlorine Free - field	mg/L	APHA4500CIG	0.05	0.43	0.70	0.51	0.64	0.69	0.73	0.68	0.74
Chlorine Total - field	mg/L	APHA4500CIG	0.05	0.63	0.90	0.68	0.69	0.82	0.80	0.76	0.81
Temperature - field	Deg. C	APHA2550B	0.1	23.1	23.5	21.8	23.5	22.0	21.8	21.6	22.5
Dissolved Oxygen - field	mg/L	APHA4500OG	1	8.4	8.4	8.7	8.4	8.5	8.6	9.0	8.5
Turbidity - field#	NTU	APHA2130B	0.1	0.36	0.59	0.46	0.32	0.19	0.30	0.26	0.33
Total Coliforms*#	MPN/100mL	PNWI01	1	<1	<1	<1	<1	<1	<1	<1	<1
<i>E.coli</i> *#	MPN/100mL	PNWI02	1	<1	<1	<1	<1	<1	<1	<1	<1
Total Plate Count*#	cfu/mL	PNWMF03	1	8	<1	30	<1	<1	15	36	<1



Certificate Of Analysis


Client: Richmond Valley Council

Report no: 18/1619

Sample No.: Sample description: Date sampled: Time sampled:	Unit	Method	LOR	18/1619/9 Evans Head High Zone 23/10/2018 09:00
pH - field	pH	APHA4500H	2	8.2
Chlorine Free - field	mg/L	APHA4500CIG	0.05	0.75
Chlorine Total - field	mg/L	APHA4500CIG	0.05	0.80
Temperature - field	Deg.C	APHA2550B	0.1	21.0
Dissolved Oxygen - field	mg/L	APHA4500OG	1	9.0
Turbidity - field#	NTU	APHA2130B	0.1	0.24
Total Coliforms*#	MPN/100mL	PNWI01	1	<1
<i>E.coli</i> *#	MPN/100mL	PNWI02	1	<1
Total Plate Count*#	cfu/mL	PNWMF03	1	60

General comments: This report must not be reproduced except in full. This report relates only to items tested as specified herein. Samples analysed between date received and date reported. Accredited for compliance with ISO/IEC 17025.
NATA accreditation does not cover the performance of this service. Tests marked with * are subcontracted.
LOR denotes 'Limit of Reporting'

Specific comments: This is the final report that supersedes the preliminary report issued on the 23.10.18


M Window
Laboratory Analyst
Approved Authoriser