



Certificate Of Analysis

Client: Richmond Valley Council
Address: Locked Bag 10
Casino NSW 2470
Contact: Aidan Macqueen
Sampled by: Mia Donnelly

Final report

Report no: 18/1654
Date received: 30/10/2018
Testing commenced: 30/10/2018
Date reported: 5/11/2018
No. of samples: 8
Revision no: 01

* **Subcontract Laboratory:** Pathology North

* **Subcontract Reference:** 341421274

RVC Consumer Weekly

Sampled in accordance with RWL 2.0 to 2.05

Sample No.: Sample description:	Unit	Method	LOR	18/1654/1 Casino Sextonville Rd 30/10/2018 12:10	18/1654/2 Casino Walker Street 30/10/2018 12:30	18/1654/3 Coraki Memorial Park 30/10/2018 11:35	18/1654/4 Woodburn Riverside Park 30/10/2018 07:15	18/1654/5 Broadwater Community Centre 30/10/2018 10:00	18/1654/6 Rileys Hill Community Centre 30/10/2018 07:55	18/1654/7 Evans Head School 30/10/2018 08:25	18/1654/8 Evans Head High Zone 30/10/2018 08:50
pH - field	pH	APHA4500H	2	7.5	7.3	7.5	8.0	8.0	8.0	8.0	8.1
Chlorine Free - field	mg/L	APHA4500CIG	0.05	1.07	0.20	0.44	0.81	0.71	0.65	0.76	0.65
Chlorine Total - field	mg/L	APHA4500CIG	0.05	1.25	0.32	0.52	0.85	0.77	0.68	0.81	0.70
Temperature - field	Deg. C	APHA2550B	0.1	25.1	24.8	25.8	22.9	21.9	22.1	22.6	21.6
Dissolved Oxygen - field	mg/L	APHA4500OG	1	8.1	8.0	8.2	8.3	8.7	8.6	8.8	8.9
Turbidity - field#	NTU	APHA2130B	0.1	2.4	0.38	0.28	0.25	0.35	0.25	0.26	0.35
Total Coliforms*#	MPN/100mL	PNWI01	1	<1	<1	<1	<1	<1	<1	<1	<1
<i>E.coli</i> *#	MPN/100mL	PNWI02	1	<1	<1	<1	<1	<1	<1	<1	<1
Total Plate Count*#	cfu/mL	PNWMF03	1	3	4	<1	2	<1	<1	2	16

General comments: This report must not be reproduced except in full. This report relates only to items tested as specified herein. Samples analysed between date received and date reported. Accredited for compliance with ISO/IEC 17025. # NATA accreditation does not cover the performance of this service. Tests marked with * are subcontracted. LOR denotes 'Limit of Reporting'

Specific comments: This is the final report that supersedes the preliminary report issued on the 31/10/18



V. Barnett
Laboratory Analyst
Approved Authoriser