



Certificate Of Analysis

Client: Richmond Valley Council
Address: Locked Bag 10
Casino NSW 2470
Contact: Aidan Macqueen
Sampled by: Gary Mead
Subcontract Laboratory: Envirolab (NATA2901)
Subcontract Reference: 204044

Final report

Report no: 18/1622
Date received: 23/10/2018
Testing commenced: 23/10/2018
Date reported: 2/11/2018
No. of samples: 2
Revision no: 00

Analysis results apply to samples as received.

Raw and Finished Weekly

Sample No.: Sample description: Date sampled: Time sampled:	Unit	Method	LOR	18/1622-1 RVC Finished Water 23/10/2018	18/1622-2 RVC Raw Water 23/10/2018
pH	pH	APHA4500H		7.1	7.6
Electrical Conductivity	µS/cm	APHA2510B	1	345	203
Total Dissolved Solids by calc	mg/L	APHA1030E	2	221	130
Dissolved Oxygen	mg/L	APHA4500OG	0.2	8.6	8.2
Fluoride - ISE	mg/L	APHA4500FC	0.05	1.09	[NA]
Colour (Apparent)	Pt-Co	RWL10.02	2	<2	100
Colour (True)	Pt-Co	RWL10.02	2	<2	44
Turbidity	NTU	APHA2130B	0.1	<0.10	21
Alkalinity (as CaCO ₃)	mg/L	APHA2320B	20	57	65
Suspended Solids	mg/L	APHA2540D	1	<1	17
Total Organic Carbon*	mg/L	Envirolab	1	2	5
Aluminium (Total)	mg/L	APHA3120B	0.005	0.040	1.25
Aluminium (Dissolved)	mg/L	APHA3120B	0.005	0.037	0.45



Certificate Of Analysis


Client: Richmond Valley Council

Report no: 18/1622

Sample No.: Sample description: Date sampled: Time sampled:	Unit	Method	LOR	18/1622-1 RVC Finished Water 23/10/2018	18/1622-2 RVC Raw Water 23/10/2018
Iron (Total)	mg/L	APHA3120B	0.005	<0.005	1.5
Iron (Dissolved)	mg/L	APHA3120B	0.005	<0.005	0.44
Manganese (Total)	mg/L	APHA3120B	0.005	<0.005	0.050
Manganese (Dissolved)	mg/L	APHA3120B	0.005	<0.005	0.013
Calcium	mg/L	APHA3120B	0.1	13.1	12.9
Magnesium	mg/L	APHA3120B	0.1	8.4	8.5
Hardness as CaCO ₃	mg/L	APHA2340B	1	67	67
Total Coliforms	MPN/100mL	APHA9223B	1	<1	3,310
<i>E.coli</i>	MPN/100mL	APHA9223B	1	<1	126
Heterotrophic Plate Count	MPN/mL	APHA9215E	2	<2	8,300

General comments: This report must not be reproduced except in full. This report relates to items tested as specified herein.
Samples tested between date received and date reported. Accredited for compliance with ISO/IEC 17025.
NATA accreditation does not cover the performance of this service. Tests marked with * are subcontracted.
LOR denotes 'Limit of Reporting'

Specific comments:


M Window
Laboratory Analyst
Approved Authoriser