



## Certificate Of Analysis

**Client:** Richmond Valley Council  
**Address:** Locked Bag 10  
Casino NSW 2470  
**Contact:** Aidan Macqueen  
**Sampled by:** Mia Donnelly

Final report

**Report no:** 19/0065  
**Date received:** 15/01/2019  
**Testing commenced:** 15/01/2019  
**Date reported:** 30/01/2019  
**No. of samples:** 3  
**Revision no:** 01

\* **Subcontract Laboratory:** Envirolab (NATA2901)

\* **Subcontract Reference:** 209759

RVC Casino Consumer Monthly

Sampled in accordance with RWL 2.0 to 2.05

Sample No.: Sample description:	Unit	Method	LOR	19/0065/1 Casino Walker Street 15/01/2019 12:25	19/0065/2 Casino North Res 15/01/2019 12:40	19/0065/3 Casino Sheppard St 15/01/2019 13:10
Fluoride - ISE	mg/L	APHA4500FC	0.05	0.78	0.64	0.78
Colour (True)	Pt-Co	RWL10.02	2	2	<2	2
Ammonia-N	mg/L	RWL 10.06	0.01	<0.01	<0.01	<0.01
Nitrogen - Nitrate-N	mg/L	RWL 10.05	0.05	<0.05	<0.05	<0.05
Nitrogen - Nitrite-N	mg/L	RWL 10.05	0.01	<0.01	<0.01	<0.01
Aluminium (Total)	mg/L	APHA3120B	0.005	0.065	0.054	0.070
Copper (Total)	mg/L	APHA3120B	0.005	0.031	0.033	0.007
Iron (Total)	mg/L	APHA3120B	0.005	0.005	<0.005	0.02
Lead (Total)	mg/L	APHA3120B	0.005	<0.005	<0.005	<0.005
Manganese (Total)	mg/L	APHA3120B	0.005	0.018	0.016	0.008
Zinc (Total)	mg/L	APHA3120B	0.005	<0.005	<0.005	<0.005
Total Trihalomethanes*	µg/L	Envirolab	1	63	57	65



## Certificate Of Analysis

**Client:** Richmond Valley Council

**Report no:** 19/0065

General comments: This report must not be reproduced except in full. This report relates only to items tested as specified herein.  
Samples analysed between date received and date reported. Accredited for compliance with ISO/IEC 17025.  
# NATA accreditation does not cover the performance of this service. Tests marked with \* are subcontracted.  
LOR denotes 'Limit of Reporting'

Specific comments:

V. Barnett  
Laboratory Analyst  
Approved Authoriser