



## Certificate Of Analysis

**Client:** Richmond Valley Council  
**Address:** Locked Bag 10  
Casino NSW 2470  
**Contact:** Aidan Macqueen  
**Sampled by:** Mia Donnelly

Final report

**Report no:** 19/0017  
**Date received:** 8/01/2019  
**Testing commenced:** 8/01/2019  
**Date reported:** 14/01/2019  
**No. of samples:** 10  
**Revision no:** 01

\* **Subcontract Laboratory:** Pathology North

\* **Subcontract Reference:** 341302535

RVC Consumer Weekly

Sampled in accordance with RWL 2.0 to 2.05

Sample No.: Sample description:	Unit	Method	LOR	19/0017/1 Casino Council Depot	19/0017/2 Casino Bruton St	19/0017/3 Casino Walker Street	19/0017/4 Coraki Memorial Park	19/0017/5 Woodburn Riverside Park	19/0017/6 Broadwater Community Centre	19/0017/7 Rileys Hill Community Centre	19/0017/8 Evans Head School
Date sampled: Time sampled:				8/01/2019 13:20	8/01/2019 12:50	8/01/2019 12:35	8/01/2019 12:10	8/01/2019 07:15	8/01/2019 10:25	8/01/2019 08:00	8/01/2019 08:30
pH - field	pH	APHA4500H	2	7.4	7.1	7.2	7.7	8.1	8.0	8.0	8.0
Chlorine Free - field	mg/L	APHA4500CIG	0.05	0.68	0.88	0.67	0.56	0.68	0.56	0.39	0.43
Chlorine Total - field	mg/L	APHA4500CIG	0.05	0.93	1.03	0.84	0.65	0.74	0.61	0.48	0.66
Temperature - field	Deg. C	APHA2550B	0.1	28.3	28.2	29.8	30.8	27.4	25.9	27.2	26.7
Dissolved Oxygen - field	mg/L	APHA4500OG	1	7.7	7.4	7.4	7.4	8.2	7.8	8.1	8.0
Turbidity - field#	NTU	APHA2130B	0.1	0.43	0.37	0.46	0.23	0.22	0.33	0.20	0.32
Total Coliforms*#	MPN/100mL	PNWI01	1	<1	<1	<1	<1	<1	<1	<1	<1
<i>E.coli</i> *#	MPN/100mL	PNWI02	1	<1	<1	<1	<1	<1	<1	<1	<1
Total Plate Count*#	cfu/mL	PNWMF03	1	3	5	<1	<1	<1	1	33	<1



## Certificate Of Analysis

**Client:** Richmond Valley Council

**Report no:** 19/0017

Sample No.: Sample description:  Date sampled: Time sampled:	Unit	Method	LOR	19/0017/9 Evans Head High Zone 8/01/2019 08:55	19/0017/10 Siversands Caravan Park 8/01/2019 09:30
pH - field	pH	APHA4500H	2	8.0	8.0
Chlorine Free - field	mg/L	APHA4500CIG	0.05	0.40	0.57
Chlorine Total - field	mg/L	APHA4500CIG	0.05	0.50	0.68
Temperature - field	Deg.C	APHA2550B	0.1	25.7	26.0
Dissolved Oxygen - field	mg/L	APHA4500OG	1	8.0	8.2
Turbidity - field#	NTU	APHA2130B	0.1	0.28	0.34
Total Coliforms*#	MPN/100mL	PNWI01	1	<1	<1
<i>E.coli</i> *#	MPN/100mL	PNWI02	1	<1	<1
Total Plate Count*#	cfu/mL	PNWMF03	1	100	1

General comments: This report must not be reproduced except in full. This report relates only to items tested as specified herein. Samples analysed between date received and date reported. Accredited for compliance with ISO/IEC 17025. # NATA accreditation does not cover the performance of this service. Tests marked with \* are subcontracted. LOR denotes 'Limit of Reporting'

Specific comments: This is the final report that supersedes the preliminary report issued on the 08/01/2019.

V. Barnett  
Laboratory Analyst  
Approved Authoriser