



Certificate Of Analysis

Client: Richmond Valley Council
Address: Locked Bag 10
 Casino NSW 2470
Contact: Aidan Macqueen
Sampled by: Gary Mead
Subcontract Laboratory: Envirolab (NATA 2901)/UUQ (NATA 11085)
Subcontract Reference: 202326 / 18-08813

Final report

Report no: 18/1497
Date received: 2/10/2018
Testing commenced: 2/10/2018
Date reported: 16/10/2018
No. of samples: 2
Revision no: 00

Analysis results apply to samples as received.

Raw and Finished Mthly

Sample No.: Sample description: Date sampled: Time sampled:	Unit	Method	LOR	18/1497-1 RVC Finished Water 2/10/2018	18/1497-2 RVC Raw Water 2/10/2018
pH	pH	APHA4500H		7.6	7.6
Electrical Conductivity	µS/cm	APHA2510B	1	370	343
Total Dissolved Solids by calc	mg/L	APHA1030E	2	237	220
Dissolved Oxygen	mg/L	APHA4500OG	0.2	9.0	8.5
Fluoride - ISE	mg/L	APHA4500FC	0.05	1.04	[NA]
Colour (Apparent)	Pt-Co	RWL10.02	2	<2	29
Colour (True)	Pt-Co	RWL10.02	2	<2	11
Turbidity	NTU	APHA2130B	0.1	0.16	5.2
Aluminium (Total)	mg/L	APHA3120B	0.005	0.14	0.34
Aluminium (Dissolved)	mg/L	APHA3120B	0.005	0.14	0.095
Iron (Total)	mg/L	APHA3120B	0.005	<0.005	0.37
Iron (Dissolved)	mg/L	APHA3120B	0.005	<0.005	0.016
Manganese (Total)	mg/L	APHA3120B	0.005	<0.005	0.072



Certificate Of Analysis

Client: Richmond Valley Council

Report no: 18/1497

Sample No.: Sample description: Date sampled: Time sampled:	Unit	Method	LOR	18/1497-1 RVC Finished Water 2/10/2018	18/1497-2 RVC Raw Water 2/10/2018
Manganese (Dissolved)	mg/L	APHA3120B	0.005	<0.005	0.005
Alkalinity (as CaCO ₃)	mg/L	APHA2320B	20	117	129
Suspended Solids	mg/L	APHA2540D	1	<1	7
Total Organic Carbon*	mg/L	Envirolab	1	3	3
Phosphorus - Total	mg/L	RWL 10.07	0.05	<0.05	0.05
Nitrogen - Nitrite-N	mg/L	RWL 10.05	0.01	<0.01	<0.01
Nitrogen - Nitrate-N	mg/L	RWL 10.05	0.05	0.05	<0.05
Dissolved Organic Carbon*	mg/L	Envirolab	1	2	3
Total Trihalomethanes*	µg/L	Envirolab	1	22	[NA]
2-methylisoborneol*	ng/L	UUQ	2	[NA]	<2
Geosmin*	ng/L	UUQ	2	[NA]	<2
Calcium	mg/L	APHA3120B	0.1	25.8	27.2
Magnesium	mg/L	APHA3120B	0.1	16.2	17.2
Hardness as CaCO ₃	mg/L	APHA2340B	1	131	139
Total Coliforms	MPN/100mL	APHA9223B	1	<1	816
<i>E. coli</i>	MPN/100mL	APHA9223B	1	<1	30
Heterotrophic Plate Count	MPN/mL	APHA9215E	2	<2	440




Certificate Of Analysis

Client: Richmond Valley Council

Report no: 18/1497

General comments: This report must not be reproduced except in full. This report relates to items tested as specified herein.
Samples tested between date received and date reported. Accredited for compliance with ISO/IEC 17025.
NATA accreditation does not cover the performance of this service. Tests marked with * are subcontracted.
LOR denotes 'Limit of Reporting'

Specific comments:


M Window
Laboratory Analyst
Approved Authoriser