



Certificate Of Analysis

Client: Richmond Valley Council
Address: Locked Bag 10
Casino NSW 2470
Contact: Aidan Macqueen
Sampled by: Gary Mead
Subcontract Laboratory: Envirolab (NATA 2901) / UUQ NATA 11085)
Subcontract Reference: 208992-209368/19-00238

Final report

Report no: 19/0004
Date received: 2/01/2019
Testing commenced: 2/01/2019
Date reported: 22/01/2019
No. of samples: 2
Revision no: 01

Analysis results apply to samples as received.

Raw and Finished Mthly

Sample No.: Sample description:	Unit	Method	LOR	19/0004-1 RVC Finished Water 2/01/2019 11:30	19/0004-2 RVC Raw Water 2/01/2019 11:00
Date sampled:					
Time sampled:					
pH	pH	APHA4500H		6.8	7.5
Electrical Conductivity	µS/cm	APHA2510B	1	339	296
Total Dissolved Solids by calc	mg/L	APHA1030E	2	217	189
Dissolved Oxygen	mg/L	APHA4500OG	0.2	10.3	9.2
Fluoride - ISE	mg/L	APHA4500FC	0.05	1.14	[NA]
Colour (Apparent)	Pt-Co	RWL10.02	2	<2	26
Colour (True)	Pt-Co	RWL10.02	2	<2	10
Turbidity	NTU	APHA2130B	0.1	0.18	5.5
Aluminium (Total)	mg/L	APHA3120B	0.005	0.050	0.22
Aluminium (Dissolved)	mg/L	APHA3120B	0.005	0.045	0.027
Iron (Total)	mg/L	APHA3120B	0.005	<0.005	0.34
Iron (Dissolved)	mg/L	APHA3120B	0.005	<0.005	0.018
Manganese (Total)	mg/L	APHA3120B	0.005	0.007	0.11



Certificate Of Analysis

Client: Richmond Valley Council

Report no: 19/0004

Sample No.: Sample description:	Unit	Method	LOR	19/0004-1 RVC Finished Water 2/01/2019 11:30	19/0004-2 RVC Raw Water 2/01/2019 11:00
Manganese (Dissolved)	mg/L	APHA3120B	0.005	<0.005	<0.005
Alkalinity (as CaCO ₃)	mg/L	APHA2320B	20	83	113
Suspended Solids	mg/L	APHA2540D	1	<1	1
Total Organic Carbon*	mg/L	Envirolab	1	2	4
Phosphorus - Total	mg/L	RWL 10.07	0.05	<0.05	0.19
Nitrogen - Nitrite-N	mg/L	RWL 10.05	0.01	<0.01	<0.01
Nitrogen - Nitrate-N	mg/L	RWL 10.05	0.05	<0.05	<0.05
Dissolved Organic Carbon*	mg/L	Envirolab	1	2	4
Total Trihalomethanes*	µg/L	Envirolab	1	20	[NA]
2-methylisoborneol*	ng/L	UUQ	2	[NA]	3
Geosmin*	ng/L	UUQ	2	[NA]	<2
Calcium	mg/L	APHA3120B	0.1	22.1	21.2
Magnesium	mg/L	APHA3120B	0.1	13.6	13.3
Hardness as CaCO ₃	mg/L	APHA2340B	1	111	108
Total Coliforms	MPN/100mL	APHA9223B	1	<1	1,203
<i>E. coli</i>	MPN/100mL	APHA9223B	1	<1	11
Heterotrophic Plate Count	MPN/mL	APHA9215E	2	<2	161



Certificate Of Analysis

Client: Richmond Valley Council

Report no: 19/0004

General comments: This report must not be reproduced except in full. This report relates to items tested as specified herein.
Samples tested between date received and date reported. Accredited for compliance with ISO/IEC 17025.
NATA accreditation does not cover the performance of this service. Tests marked with * are subcontracted.
LOR denotes 'Limit of Reporting'

Specific comments: This is the final report that supersedes the preliminary report issued on the 14/01/19.

V. Barnett
Laboratory Analyst
Approved Authoriser