



Certificate Of Analysis

Client: Richmond Valley Council
Address: Locked Bag 10
Casino NSW 2470
Contact: Aidan Macqueen
Sampled by: Mia Donnelly
Subcontract Laboratory: Envirolab (NATA2901)
Subcontract Reference: 209368

Final report

Report no: 19/0021
Date received: 8/01/2019
Testing commenced: 8/01/2019
Date reported: 22/01/2019
No. of samples: 2
Revision no: 00

Raw and Finished Weekly

Analysis results apply to samples as received.

Sample No.: Sample description:	Unit	Method	LOR	19/0021-1 RVC Finished Water 8/01/2019 11:30	19/0021-2 RVC Raw Water 8/01/2019 11:00
pH	pH	APHA4500H		7.3	7.8
Electrical Conductivity	µS/cm	APHA2510B	1	352	302
Total Dissolved Solids by calc	mg/L	APHA1030E	2	225	193
Dissolved Oxygen	mg/L	APHA4500OG	0.2	8.2	7.9
Fluoride - ISE	mg/L	APHA4500FC	0.05	1.09	[NA]
Colour (Apparent)	Pt-Co	RWL10.02	2	<2	32
Colour (True)	Pt-Co	RWL10.02	2	<2	10
Turbidity	NTU	APHA2130B	0.1	0.10	5.6
Alkalinity (as CaCO ₃)	mg/L	APHA2320B	20	85	113
Suspended Solids	mg/L	APHA2540D	1	<1	8
Total Organic Carbon*	mg/L	Envirolab	1	2	4
Aluminium (Total)	mg/L	APHA3120B	0.005	0.042	0.20
Aluminium (Dissolved)	mg/L	APHA3120B	0.005	0.041	0.018



Certificate Of Analysis

Client: Richmond Valley Council

Report no: 19/0021

Sample No.: Sample description: Date sampled: Time sampled:	Unit	Method	LOR	19/0021-1 RVC Finished Water 8/01/2019 11:30	19/0021-2 RVC Raw Water 8/01/2019 11:00
Iron (Total)	mg/L	APHA3120B	0.005	<0.005	0.29
Iron (Dissolved)	mg/L	APHA3120B	0.005	<0.005	0.014
Manganese (Total)	mg/L	APHA3120B	0.005	0.008	0.078
Manganese (Dissolved)	mg/L	APHA3120B	0.005	<0.005	<0.005
Calcium	mg/L	APHA3120B	0.1	20.9	21.0
Magnesium	mg/L	APHA3120B	0.1	13.2	13.1
Hardness as CaCO ₃	mg/L	APHA2340B	1	107	106
Total Coliforms	MPN/100mL	APHA9223B	1	<1	1,120
<i>E.coli</i>	MPN/100mL	APHA9223B	1	<1	7
Heterotrophic Plate Count	MPN/mL	APHA9215E	2	<2	623

General comments: This report must not be reproduced except in full. This report relates to items tested as specified herein.
Samples tested between date received and date reported. Accredited for compliance with ISO/IEC 17025.
NATA accreditation does not cover the performance of this service. Tests marked with * are subcontracted.
LOR denotes 'Limit of Reporting'

Specific comments:

V. Barnett
Laboratory Analyst
Approved Authoriser