



Certificate Of Analysis

Client: Richmond Valley Council
Address: Locked Bag 10
Casino NSW 2470
Contact: Aidan Macqueen
Sampled by: Mia Donnelly

Final report

Report no: 19/0018 00
Date received: 8/01/2019
Testing commenced: 8/01/2019
Date reported: 14/01/2019
No. of samples: 3

Sampled in accordance with RWL 2.0 to 2.05

Weekly Fluoride

Sample No.: Sample description:	Unit	Method	LOR	19/0018/1 Casino Walker Street 8/01/2019 12:35	19/0018/2 Casino Bruton St 8/01/2019 12:50	19/0018/3 Casino Council Depot 8/01/2019 13:20
Fluoride - ISE	mg/L	APHA4500FC	0.05	1.11	1.10	0.56
Iron (Total)	mg/L	APHA3120B	0.005	0.04	<0.005	0.01
Manganese (Total)	mg/L	APHA3120B	0.005	0.014	0.014	0.018

General comments: This report must not be reproduced except in full. This report relates only to the items tested as specified herein. Samples analysed between date received and date reported. Accredited for compliance with ISO/IEC 17025 # NATA accreditation does not cover the performance of this service. Tests marked with * are subcontracted. LOR denotes 'Limit of Reporting'

Specific comments:

V. Barnett
Laboratory Analyst
Approved Authoriser