



## Certificate Of Analysis

**Client:** Richmond Valley Council  
**Address:** Locked Bag 10  
Casino NSW 2470  
**Contact:** Aidan Macqueen  
**Sampled by:** Mia Donnelly

Final report

**Report no:** 19/0435  
**Date received:** 12/03/2019  
**Testing commenced:** 12/03/2019  
**Date reported:** 25/03/2019  
**No. of samples:** 3  
**Revision no:** 00

\* **Subcontract Laboratory:** Envirolab (NATA2901)

\* **Subcontract Reference:** 213552

RVC Casino Consumer Monthly

Sampled in accordance with RWL 2.0 to 2.05

Sample No.: Sample description:	Unit	Method	LOR	19/0435/1 Casino Walker Street 12/03/2019 13:05	19/0435/2 Casino Showground 12/03/2019 12:50	19/0435/3 Casino South Res 12/03/2019 12:35
Fluoride - ISE	mg/L	APHA4500FC	0.05	0.997	1.05	1.01
Colour (True)	Pt-Co	RWL10.02	2	<2	<2	<2
Ammonia-N	mg/L	RWL 10.06	0.01	<0.01	<0.01	<0.01
Nitrogen - Nitrate-N	mg/L	RWL 10.05	0.05	<0.05	<0.05	<0.05
Nitrogen - Nitrite-N	mg/L	RWL 10.05	0.01	<0.01	<0.01	<0.01
Aluminium (Total)	mg/L	APHA3120B	0.005	0.068	0.066	0.072
Copper (Total)	mg/L	APHA3120B	0.005	0.040	0.032	0.024
Iron (Total)	mg/L	APHA3120B	0.005	<0.005	<0.005	<0.005
Lead (Total)	mg/L	APHA3120B	0.005	<0.005	<0.005	<0.005
Manganese (Total)	mg/L	APHA3120B	0.005	<0.005	<0.005	<0.005
Zinc (Total)	mg/L	APHA3120B	0.005	<0.005	0.008	0.032
Total Trihalomethanes*	µg/L	Envirolab	1	71	121	107



## Certificate Of Analysis

**Client:** Richmond Valley Council

**Report no:** 19/0435

**General comments:** This report must not be reproduced except in full. This report relates only to items tested as specified herein. Samples analysed between date received and date reported. Accredited for compliance with ISO/IEC 17025. # NATA accreditation does not cover the performance of this service. Tests marked with \* are subcontracted. LOR denotes 'Limit of Reporting'

**Specific comments:**

V. Barnett  
Laboratory Analyst  
Approved Authoriser