



Certificate Of Analysis

Client: Richmond Valley Council
Address: Locked Bag 10
Casino NSW 2470
Contact: Aidan Macqueen
Sampled by: Mia Donnelly

Final report

Report no: 19/0434
Date received: 12/03/2019
Testing commenced: 12/03/2019
Date reported: 15/03/2019
No. of samples: 10
Revision no: 01

* **Subcontract Laboratory:** Pathology North

* **Subcontract Reference:** 349648413

RVC Consumer Weekly

Sampled in accordance with RWL 2.0 to 2.05

Sample No.: Sample description:	Unit	Method	LOR	19/0434/1 Casino Showground	19/0434/2 Casino Walker Street	19/0434/3 Casino South Res	19/0434/4 Coraki Memorial Park	19/0434/5 Box Ridge Community	19/0434/6 Woodburn Riverside Park	19/0434/7 Broadwater Community Centre	19/0434/8 Rileys Hill Community Centre
Date sampled: Time sampled:				12/03/2019 12:50	12/03/2019 13:05	12/03/2019 12:35	12/03/2019 12:05	12/03/2019 11:40	12/03/2019 07:05	12/03/2019 10:10	12/03/2019 07:50
pH - field	pH	APHA4500H	2	7.8	7.5	7.6	7.6	7.6	8.1	8.0	8.0
Chlorine Free - field	mg/L	APHA4500CIG	0.05	0.34	0.93	0.81	0.52	0.66	0.79	0.25	0.33
Chlorine Total - field	mg/L	APHA4500CIG	0.05	0.52	1.13	0.99	0.56	0.73	0.85	0.34	0.41
Temperature - field	Deg. C	APHA2550B	0.1	29.1	29.2	27.5	30.7	27.4	27.7	26.7	27.7
Dissolved Oxygen - field	mg/L	APHA4500OG	1	7.4	7.4	7.5	7.3	7.6	7.7	7.9	7.8
Turbidity - field#	NTU	APHA2130B	0.1	0.23	0.24	0.26	0.23	0.28	0.26	0.29	0.24
Total Coliforms*#	MPN/100mL	PNWI01	1	<1	<1	<1	<1	<1	<1	<1	<1
<i>E.coli</i> *#	MPN/100mL	PNWI02	1	<1	<1	<1	<1	<1	<1	<1	<1
Total Plate Count*#	cfu/mL	PNWMF03	1	6	18	5	1	4	74	<1	10



Certificate Of Analysis


Client: Richmond Valley Council

Report no: 19/0434

Sample No.: Sample description: Date sampled: Time sampled:	Unit	Method	LOR	19/0434/9 Evans Head School 12/03/2019 08:20	19/0434/10 Evans Head High Zone 12/03/2019 08:45
pH - field	pH	APHA4500H	2	8.1	8.1
Chlorine Free - field	mg/L	APHA4500CIG	0.05	0.58	0.43
Chlorine Total - field	mg/L	APHA4500CIG	0.05	0.70	0.48
Temperature - field	Deg.C	APHA2550B	0.1	26.7	26.0
Dissolved Oxygen - field	mg/L	APHA4500OG	1	7.6	7.7
Turbidity - field#	NTU	APHA2130B	0.1	0.36	0.22
Total Coliforms*#	MPN/100mL	PNWI01	1	<1	<1
<i>E.coli</i> *#	MPN/100mL	PNWI02	1	<1	<1
Total Plate Count*#	cfu/mL	PNWMF03	1	3	33

General comments: This report must not be reproduced except in full. This report relates only to items tested as specified herein. Samples analysed between date received and date reported. Accredited for compliance with ISO/IEC 17025.
NATA accreditation does not cover the performance of this service. Tests marked with * are subcontracted.
LOR denotes 'Limit of Reporting'

Specific comments: This is the final report that supersedes the preliminary report issued on the 12/03/19


M Window
Laboratory Analyst
Approved Authoriser