



Certificate Of Analysis

Client: Richmond Valley Council
Address: Locked Bag 10
Casino NSW 2470
Contact: Aidan Macqueen
Sampled by: Gary Mead
Subcontract Laboratory: Envirolab (NATA2901)
Subcontract Reference: 212397

Final report

Report no: 19/0327
Date received: 26/02/2019
Testing commenced: 26/02/2019
Date reported: 8/03/2019
No. of samples: 2
Revision no: 00

Analysis results apply to samples as received.

Raw and Finished Weekly

Sample No.: Sample description:	Unit	Method	LOR	19/0327-1 RVC Finished Water 26/02/2019 11:30	19/0327-2 RVC Raw Water 26/02/2019 09:40
Date sampled:					
Time sampled:					
pH	pH	APHA4500H		7.8	8.5
Electrical Conductivity	µS/cm	APHA2510B	1	511	407
Total Dissolved Solids by calc	mg/L	APHA1030E	2	327	260
Dissolved Oxygen	mg/L	APHA4500OG	0.2	8.1	7.4
Fluoride - ISE	mg/L	APHA4500FC	0.05	1.29	[NA]
Colour (Apparent)	Pt-Co	RWL10.02	2	<2	52
Colour (True)	Pt-Co	RWL10.02	2	<2	11
Turbidity	NTU	APHA2130B	0.1	0.15	6.2
Alkalinity (as CaCO ₃)	mg/L	APHA2320B	20	139	148
Suspended Solids	mg/L	APHA2540D	1	<1	14
Total Organic Carbon*	mg/L	Envirolab	1	2	3
Aluminium (Total)	mg/L	APHA3120B	0.005	0.095	0.18
Aluminium (Dissolved)	mg/L	APHA3120B	0.005	0.094	0.027



Certificate Of Analysis


Client: Richmond Valley Council

Report no: 19/0327

Sample No.: Sample description:	Unit	Method	LOR	19/0327-1 RVC Finished Water 26/02/2019 11:30	19/0327-2 RVC Raw Water 26/02/2019 09:40
Date sampled:					
Time sampled:					
Iron (Total)	mg/L	APHA3120B	0.005	<0.005	0.25
Iron (Dissolved)	mg/L	APHA3120B	0.005	<0.005	0.011
Manganese (Total)	mg/L	APHA3120B	0.005	<0.005	0.11
Manganese (Dissolved)	mg/L	APHA3120B	0.005	<0.005	<0.005
Calcium	mg/L	APHA3120B	0.1	31.0	29.7
Magnesium	mg/L	APHA3120B	0.1	19.0	18.3
Hardness as CaCO ₃	mg/L	APHA2340B	1	156	150
Total Coliforms	MPN/100mL	APHA9223B	1	<1	100,700
<i>E.coli</i>	MPN/100mL	APHA9223B	1	<1	5
Heterotrophic Plate Count	MPN/mL	APHA9215E	2	<2	5,900

General comments: This report must not be reproduced except in full. This report relates to items tested as specified herein.
Samples tested between date received and date reported. Accredited for compliance with ISO/IEC 17025.
NATA accreditation does not cover the performance of this service. Tests marked with * are subcontracted.
LOR denotes 'Limit of Reporting'

Specific comments:


M Window
Laboratory Analyst
Approved Authoriser