



Certificate Of Analysis

Client: Richmond Valley Council
Address: Locked Bag 10
Casino NSW 2470
Contact: David Cash
Sampled by: Mia Donnelly

Final report

Report no: 19/0614
Date received: 9/04/2019
Testing commenced: 9/04/2019
Date reported: 22/04/2019
No. of samples: 3
Revision no: 00

* **Subcontract Laboratory:** Envirolab (NATA2901)

* **Subcontract Reference:** 215458

RVC Casino Consumer Monthly

Sampled in accordance with RWL 2.0 to 2.05

Sample No.: Sample description:	Unit	Method	LOR	19/0614/1 Casino Walker Street 9/04/2019 12:25	19/0614/2 Casino North Res 9/04/2019 12:40	19/0614/3 Casino Sheppard St 9/04/2019 13:05
Fluoride - ISE	mg/L	APHA4500FC	0.05	1.04	1.04	1.04
Colour (True)	Pt-Co	RWL10.02	2	2	<2	<2
Ammonia-N	mg/L	RWL 10.06	0.01	<0.01	<0.01	<0.01
Nitrogen - Nitrate-N	mg/L	RWL 10.05	0.05	0.35	0.23	0.42
Nitrogen - Nitrite-N	mg/L	RWL 10.05	0.01	<0.01	<0.01	<0.01
Aluminium (Total)	mg/L	APHA3120B	0.005	0.093	0.10	0.072
Copper (Total)	mg/L	APHA3120B	0.005	0.032	0.029	0.007
Iron (Total)	mg/L	APHA3120B	0.005	0.01	<0.005	0.01
Lead (Total)	mg/L	APHA3120B	0.005	<0.005	<0.005	<0.005
Manganese (Total)	mg/L	APHA3120B	0.005	0.006	0.007	0.006
Zinc (Total)	mg/L	APHA3120B	0.005	<0.005	<0.005	<0.005
Total Trihalomethanes*	µg/L	Envirolab	1	103	71	117



Certificate Of Analysis

Client: Richmond Valley Council

Report no: 19/0614

General comments: This report must not be reproduced except in full. This report relates only to items tested as specified herein. Samples analysed between date received and date reported. Accredited for compliance with ISO/IEC 17025. # NATA accreditation does not cover the performance of this service. Tests marked with * are subcontracted. LOR denotes 'Limit of Reporting'
< denotes less than; > denotes greater than; ND denotes 'not detected'

Specific comments:

A. Hawthorne
Laboratory Manager
Approved Authoriser