

Report no:

19/0522

Certificate Of Analysis

Client: Richmond Valley Council

Address:

Total Plate Count*#

E.coli*#

Final report

PNWI02

PNWMF03

MPN/100mL

cfu/mL

Locked Bag 10 26/03/2019 Date received:

RVC Consumer Weekly

26/03/2019 Casino NSW 2470 **Testing commenced:**

Aidan Macqueen Date reported: 1/04/2019 Contact: Sampled by: Mia Donnelly No. of samples: 9

01 * Subcontract Laboratory: Pathology North Revision no:

<1

1

* Subcontract Reference: 349648826 Sampled in accordance with RWL 2.0 to 2.05

Sample No.: Sample desciption: Date sampled: Time sampled:		Method	LOR	19/0522/1 Casino Bruton St 26/03/2019 13:30	19/0522/2 Casino Council Depot 26/03/2019 13:00	19/0522/3 Casino Walker Street 26/03/2019 12:45	19/0522/4 Coraki Memorial Park 26/03/2019 12:15	19/0522/5 Woodburn Riverside Park 26/03/2019 07:15	19/0522/6 Broadwater Community Centre 26/03/2019 10:15	19/0522/7 Rileys Hill Community Centre 26/03/2019 08:05	19/0522/8 Evans Head School 26/03/2019 08:30
pH - field	рН	APHA4500H	2	7.4	7.4	7.5	7.7	8.1	8.1	8.1	8.2
Chlorine Free - field	mg/L	APHA4500CIG	0.05	0.28	0.37	0.36	0.50	0.61	0.15	<u>0.05</u>	0.66
Chlorine Total - field	mg/L	APHA4500CIG	0.05	0.43	0.61	0.58	0.56	0.70	0.21	<u>0.10</u>	0.74
Temperature - field	Deg. C	APHA2550B	0.1	27.5	27.8	28.6	28.3	27.8	26.7	27.2	27.4
Dissolved Oxygen - field	mg/L	APHA4500OG	1	7.3	7.3	7.5	7.7	8.5	7.8	8.0	7.9
Turbidity - field#	NTU	APHA2130B	0.1	0.32	0.34	0.41	0.20	0.38	0.28	0.25	0.26
Total Coliforms*#	MPN/100mL	PNWI01	1	<1	<1	<1	<1	<1	<1	<1	<1

<1

15

<1

<1

<1

2

<1

160

<1

28

<1

>200

<1

2





Environmental Analysis - Water Sampling - Data Management

Certificate Of Analysis

Client: Richmond Valley Council 19/0522 Report no:

Sample No.: Sample desciption: Date sampled: Time sampled:	Unit	Method	LOR	19/0522/9 Evans Head High Zone 26/03/2019 08:55
pH - field	рН	APHA4500H	2	8.2
Chlorine Free - field	mg/L	APHA4500CIG	0.05	0.47
Chlorine Total - field	mg/L	APHA4500CIG	0.05	0.54
Temperature - field	Deg. C	APHA2550B	0.1	26.4
Dissolved Oxygen - field	mg/L	APHA4500OG	1	8.0
Turbidity - field#	NTU	APHA2130B	0.1	0.22
Total Coliforms*#	MPN/100mL	PNWI01	1	<1
E.coli*#	MPN/100mL	PNWI02	1	<1
Total Plate Count*#	cfu/mL	PNWMF03	1	60

General comments: This report must not be reproduced except in full. This report relates only to items tested as specified herein.

Samples analysed between date received and date reported. Accredited for compliance with ISO/IEC 17025. # NATA accreditation does not cover the performance of this service. Tests marked with * are subcontracted.

LOR denotes 'Limit of Reporting'

This is the final report that supersedes the preliminary report issued on the 26.03.19 Specific comments:

> Laboratory Manager Approved Authoriser