



## Certificate Of Analysis

**Client:** Richmond Valley Council  
**Address:** Locked Bag 10  
Casino NSW 2470  
**Contact:** David Cash  
**Sampled by:** AH

Final report

**Report no:** 19/0702 00  
**Date received:** 23/04/2019  
**Testing commenced:** 23/04/2019  
**Date reported:** 30/04/2019  
**No. of samples:** 3


Sampled in accordance with RWL 2.0 to 2.05

Weekly Fluoride

Sample No.: Sample description:	Unit	Method	LOR	19/0702/1 Casino Council Depot 23/04/2019	19/0702/2 Casino Bruton St 23/04/2019	19/0702/3 Casino Walker Street 23/04/2019
Fluoride - ISE	mg/L	APHA4500FC	0.05	0.99	1.02	1.02
Iron (Total)	mg/L	APHA3120B	0.005	0.01	0.005	0.1
Manganese (Total)	mg/L	APHA3120B	0.005	0.006	0.006	<0.005

General comments: This report must not be reproduced except in full. This report relates only to the items tested as specified herein. Samples analysed between date received and date reported. Accredited for compliance with ISO/IEC 17025 # NATA accreditation does not cover the performance of this service. Tests marked with \* are subcontracted. LOR denotes 'Limit of Reporting' < denotes less than; > denotes greater than; ND denotes 'not detected'

Specific comments:

  
A. Hawthorne  
Laboratory Manager  
Approved Authoriser