



Certificate Of Analysis

Client: Richmond Valley Council
Address: Locked Bag 10
Casino NSW 2470
Contact: David Cash
Sampled by: Malcolm Window / Allison Hawthorne
*** Subcontract Laboratory:** Pathology North
*** Subcontract Reference:** 358895457
Sampled in accordance with RWL 2.0 to 2.05

Final report


Report no: 19/0797
Date received: 14/05/2019
Testing commenced: 14/05/2019
Date reported: 20/05/2019
No. of samples: 8
Revision no: 01

RVC Consumer Weekly

Sample No.: Sample description:	Unit	Method	LOR	19/0797/1 Casino Sextonville Rd 14/05/2019 13:10	19/0797/2 Casino Walker Street 14/05/2019 13:25	19/0797/3 Coraki Memorial Park 14/05/2019 12:40	19/0797/4 Woodburn Riverside Park 14/05/2019 10:30	19/0797/5 Broadwater Community Centre 14/05/2019 11:50	19/0797/6 Rileys Hill Community Centre 14/05/2019 11:25	19/0797/7 Evans Head School 14/05/2019 10:40	19/0797/8 Evans Head High Zone 14/05/2019 11:15
pH - field	pH	APHA4500H	2	7.8	7.7	7.8	8.0	8.2	8.1	8.4	8.5
Chlorine Free - field	mg/L	APHA4500CIG	0.05	0.41	0.61	0.43	0.52	0.40	0.32	0.77	0.54
Chlorine Total - field	mg/L	APHA4500CIG	0.05	0.83	0.94	0.73	0.71	0.60	0.42	1.03	0.88
Temperature - field	Deg. C	APHA2550B	0.1	23.2	22.5	23.6	22.2	22.0	21.3	22.4	21.8
Dissolved Oxygen - field	mg/L	APHA4500OG	1	8.5	8.5	8.1	8.2	8.3	8.2	7.9	8.1
Turbidity - field#	NTU	APHA2130B	0.1	0.36	0.35	0.34	0.37	0.25	0.29	0.24	0.27
Total Coliforms*#	MPN/100mL	PNWI01	1	<1	<1	<1	<1	<1	<1	<1	<1
<i>E.coli</i> *#	MPN/100mL	PNWI02	1	<1	<1	<1	<1	<1	<1	<1	<1
Total Plate Count*#	cfu/mL	PNWMF03	1	9	8	8	8	1	2	6	86

General comments: This report must not be reproduced except in full. This report relates only to items tested as specified herein.
Samples analysed between date received and date reported. Accredited for compliance with ISO/IEC 17025 - Testing
NATA accreditation does not cover the performance of this service. Tests marked with * are subcontracted.
LOR denotes 'Limit of Reporting' < denotes less than; > denotes greater than; ND denotes 'not detected'
The results of the tests, calibrations and/or measurements included in this document are traceable to Australian/national standards

Specific comments: This is the final report that supersedes the preliminary report issued on the 14.5.19


M Window
Laboratory Analyst
Approved Authoriser