



Certificate Of Analysis

Client: Richmond Valley Council

Address: Locked Bag 10
Casino NSW 2470

Contact: David Cash

Sampled by: Mia Donnelly

* **Subcontract Laboratory:** Envirolab (NATA 2901)

* **Subcontract Reference:** 219480

Sampled in accordance with RWL 2.0 to 2.05

Final report

RVC Casino Consumer Monthly

Report no: 19/0955

Date received: 11/06/2019

Testing commenced: 11/06/2019

Date reported: 24/06/2019

No. of samples: 2

Revision no: 00

Sample No.: Sample description:	Unit	Method	LOR	19/0955/1 Casino Walker Street 11/06/2019 12:25	19/0955/2 Casino Sextonville Rd 11/06/2019 12:05
Fluoride - ISE	mg/L	APHA4500FC	0.05	1.07	1.08
Colour (True)	Pt-Co	RWL10.02	2	<2	<2
Ammonia-N	mg/L	RWL 10.06	0.01	<0.01	<0.01
Nitrogen - Nitrate-N	mg/L	RWL 10.05	0.05	<0.05	<0.05
Nitrogen - Nitrite-N	mg/L	RWL 10.05	0.01	<0.01	<0.01
Aluminium (Total)	mg/L	APHA3120B	0.005	0.13	0.064
Copper (Total)	mg/L	APHA3120B	0.005	0.018	0.008
Iron (Total)	mg/L	APHA3120B	0.005	0.005	0.02
Lead (Total)	mg/L	APHA3120B	0.005	<0.005	<0.005
Manganese (Total)	mg/L	APHA3120B	0.005	<0.005	<0.005
Zinc (Total)	mg/L	APHA3120B	0.005	<0.005	<0.005
Total Trihalomethanes*	µg/L	Envirolab	1	49	89



Certificate Of Analysis

Client: Richmond Valley Council

Report no: 19/0955

General comments: This report must not be reproduced except in full. This report relates only to items tested as specified herein.
Samples analysed between date received and date reported. Accredited for compliance with ISO/IEC 17025 - Testing
NATA accreditation does not cover the performance of this service. Tests marked with * are subcontracted.
LOR denotes 'Limit of Reporting' < denotes less than; > denotes greater than; ND denotes 'not detected'
The results of the tests, calibrations and/or measurements included in this document are traceable to Australian/national standards

Specific comments:

A. Hawthorne
Laboratory Manager
Approved Authoriser