



Certificate Of Analysis

Client: Richmond Valley Council
Address: Locked Bag 10
Casino NSW 2470
Contact: David Cash
Sampled by: Mia

Final report

Report no: 19/1003 00
Date received: 18/06/2019
Testing commenced: 18/06/2019
Date reported: 24/06/2019
No. of samples: 3


Sampled in accordance with RWL 2.0 to 2.05

Weekly Fluoride

Sample No.: Sample description:	Unit	Method	LOR	19/1003/1 Casino Bruton St	19/1003/2 Casino Council Depot	19/1003/3 Casino Walker Street
Date sampled: Time sampled:				18/06/2019 12:25	18/06/2019 12:55	18/06/2019 12:10
Fluoride - ISE	mg/L	APHA4500FC	0.05	0.99	1.00	0.99
Iron (Total)	mg/L	APHA3120B	0.005	0.01	0.01	<0.005
Manganese (Total)	mg/L	APHA3120B	0.005	<0.005	0.005	<0.005

General comments: This report must not be reproduced except in full. This report relates only to the items tested as specified herein.
Samples analysed between date received and date reported. Accredited for compliance with ISO/IEC 17025 - Testing
NATA accreditation does not cover the performance of this service. Tests marked with * are subcontracted.
LOR denotes 'Limit of Reporting' < denotes less than; > denotes greater than; ND denotes 'not detected'
The results of the tests, calibrations and/or measurements included in this document are traceable to Australian/national standards

Specific comments:



A. Hawthorne
Laboratory Manager
Approved Authoriser