



## Certificate Of Analysis

**Client:** Richmond Valley Council  
**Address:** Locked Bag 10  
 Casino NSW 2470  
**Contact:** David Cash  
**Sampled by:** Mia Donnelly  
 \* **Subcontract Laboratory:** NSW Health Pathology  
 \* **Subcontract Reference:** 359076954  
*Sampled in accordance with RWL 2.0 to 2.05*

Final report

**Report no:** 19/1147  
**Date received:** 16/07/2019  
**Testing commenced:** 16/07/2019  
**Date reported:** 22/07/2019  
**No. of samples:** 9  
**Revision no:** 01

RVC Consumer Weekly

Sample No.: Sample description:  Date sampled: Time sampled:	Unit	Method	LOR	19/1147/1 Casino Council Depot 16/07/2019 12:35	19/1147/2 Casino Bruton St 16/07/2019 12:10	19/1147/3 Casino Walker Street 16/07/2019 11:55	19/1147/4 Coraki Memorial Park 16/07/2019 11:30	19/1147/5 Woodburn Riverside Park 16/07/2019 07:10	19/1147/6 Broadwater Community Centre 16/07/2019 09:45	19/1147/7 Rileys Hill Community Centre 16/07/2019 07:55	19/1147/8 Evans Head School 16/07/2019 09:05
pH - field	pH	APHA4500H	2	7.5	7.4	7.4	7.8	7.8	8.0	8.0	8.0
Chlorine Free - field	mg/L	APHA4500CIG	0.05	0.62	0.96	1.02	0.65	1.02	0.81	0.81	0.92
Chlorine Total - field	mg/L	APHA4500CIG	0.05	0.93	1.16	1.23	0.75	1.23	0.95	0.92	1.05
Temperature - field	Deg. C	APHA2550B	0.1	17.7	15.6	16.9	15.9	14.8	16.1	14.4	15.4
Dissolved Oxygen - field	mg/L	APHA4500OG	1	9.5	9.5	9.6	9.6	9.5	9.7	10.4	9.1
Turbidity - field#	NTU	APHA2130B	0.1	0.36	0.92	0.35	0.18	0.11	0.19	0.16	0.12
Total Coliforms*#	MPN/100mL	PNWI01	1	<1	<1	<1	<1	<1	<1	<1	<1
<i>E.coli</i> *#	MPN/100mL	PNWI02	1	<1	<1	<1	<1	<1	<1	<1	<1
Total Plate Count*#	cfu/mL	PNWMF03	1	1	1	<1	3	<1	2	7	9



## Certificate Of Analysis

**Client:** Richmond Valley Council

**Report no:** 19/1147

Sample No.: Sample description:  Date sampled: Time sampled:	Unit	Method	LOR	19/1147/9 Evans Head High Zone 16/07/2019 08:45
pH - field	pH	APHA4500H	2	8.1
Chlorine Free - field	mg/L	APHA4500CIG	0.05	0.60
Chlorine Total - field	mg/L	APHA4500CIG	0.05	0.69
Temperature - field	Deg.C	APHA2550B	0.1	14.7
Dissolved Oxygen - field	mg/L	APHA4500OG	1	9.4
Turbidity - field#	NTU	APHA2130B	0.1	0.14
Total Coliforms*#	MPN/100mL	PNWI01	1	<1
<i>E.coli</i> *#	MPN/100mL	PNWI02	1	<1
Total Plate Count*#	cfu/mL	PNWMF03	1	7

General comments: This report must not be reproduced except in full. This report relates only to items tested as specified herein.  
Samples analysed between date received and date reported. Accredited for compliance with ISO/IEC 17025 - Testing  
# NATA accreditation does not cover the performance of this service. Tests marked with \* are subcontracted.  
LOR denotes 'Limit of Reporting' < denotes less than; > denotes greater than; ND denotes 'not detected'  
The results of the tests, calibrations and/or measurements included in this document are traceable to Australian/national standards

Specific comments: This is the final report that supersedes the preliminary report issued on the 16.7.19.

A. Hawthorne  
Laboratory Manager  
Approved Authoriser