



Certificate Of Analysis

Client: Richmond Valley Council
Address: Locked Bag 10
Casino NSW 2470
Contact: Sandeep Chugh
Sampled by: Gary Mead
Subcontract Laboratory: Envirolab (NATA2901)
Subcontract Reference: 223196

Final report

Report no: 19/1222
Date received: 30/07/2019
Testing commenced: 30/07/2019
Date reported: 9/08/2019
No. of samples: 2
Revision no: 00

Analysis results apply to samples as received.

Raw and Finished Weekly

Sample No.: Sample description:	Unit	Method	LOR	19/1222-1 RVC Finished Water 30/07/2019 11:30	19/1222-2 RVC Raw Water 30/07/2019 11:30
pH	pH	APHA4500H		7.4	7.8
Electrical Conductivity	µS/cm	APHA2510B	1	334	269
Total Dissolved Solids by calc	mg/L	APHA1030E	2	214	172
Dissolved Oxygen	mg/L	APHA4500OG	0.2	9.93	9.6
Fluoride - ISE	mg/L	APHA4500FC	0.05	1.09	[NA]
Colour (Apparent)	Pt-Co	RWL10.02	2	<2	36
Colour (True)	Pt-Co	RWL10.02	2	<2	11
Turbidity	NTU	APHA2130B	0.1	<0.10	4.5
Alkalinity (as CaCO ₃)	mg/L	APHA2320B	20	90	89
Suspended Solids	mg/L	APHA2540D	1	1	4
Total Organic Carbon*	mg/L	Envirolab	1	2	3
Aluminium (Total)	mg/L	APHA3120B	0.005	0.043	0.23
Aluminium (Dissolved)	mg/L	APHA3120B	0.005	0.037	0.011



Certificate Of Analysis

Client: Richmond Valley Council

Report no: 19/1222

Sample No.: Sample description:	Unit	Method	LOR	19/1222-1 RVC Finished Water 30/07/2019 11:30	19/1222-2 RVC Raw Water 30/07/2019 11:30
Date sampled:					
Time sampled:					
Iron (Total)	mg/L	APHA3120B	0.005	<0.005	0.33
Iron (Dissolved)	mg/L	APHA3120B	0.005	<0.005	0.026
Manganese (Total)	mg/L	APHA3120B	0.005	<0.005	0.025
Manganese (Dissolved)	mg/L	APHA3120B	0.005	<0.005	<0.005
Calcium	mg/L	APHA3120B	0.1	16.5	16.9
Magnesium	mg/L	APHA3120B	0.1	10.9	11.0
Hardness as CaCO ₃	mg/L	APHA2340B	1	86	87
Total Coliforms	MPN/100mL	APHA9223B	1	<1	210
<i>E.coli</i>	MPN/100mL	APHA9223B	1	<1	10
Heterotrophic Plate Count	MPN/mL	APHA9215E	2	<2	280

General comments: This report must not be reproduced except in full. This report relates to items tested as specified herein.
Samples tested between date received and date reported. Accredited for compliance with ISO/IEC 17025 - Testing
NATA accreditation does not cover the performance of this service. Tests marked with * are subcontracted.
LOR denotes 'Limit of Reporting' < denotes less than; > denotes greater than; ND denotes 'not detected'
The results of the tests, calibrations and/or measurements included in this document are traceable to Australian/national standards

Specific comments:

M Window
Laboratory Analyst
Approved Authoriser