



Certificate Of Analysis

Client: Richmond Valley Council

Address: Locked Bag 10
Casino NSW 2470

Contact: Sandeep Chugh

Sampled by: Jacob Arthur / Adrian Leader

* **Subcontract Laboratory:** NSW Health Pathology

* **Subcontract Reference:** 341304096

Sampled in accordance with RWL 2.0 to 2.05

Final report

RVC Consumer Weekly

Report no: 19/1443

Date received: 5/09/2019

Testing commenced: 5/09/2019

Date reported: 10/09/2019

No. of samples: 9

Revision no: 01

Sample No.: Sample description:	Unit	Method	LOR	19/1443/1 Casino Sextonville Rd 4/09/2019 10:35	19/1443/2 Casino Walker Street 4/09/2019 09:13	19/1443/3 Coraki Memorial Park 5/09/2019 14:23	19/1443/4 Box Ridge Community 5/09/2019 14:07	19/1443/5 Woodburn Riverside Park 5/09/2019 10:22	19/1443/6 Broadwater Community Centre 5/09/2019 11:07	19/1443/7 Rileys Hill Community Centre 5/09/2019 10:52	19/1443/8 Evans Head School 5/09/2019 11:40
pH - field	pH	APHA4500H	2	7.7	7.6	7.7	7.6	7.9	8.0	8.0	8.0
Chlorine Free - field	mg/L	APHA4500CIG	0.05	0.54	1.19	1.23	1.17	0.68	0.99	0.84	0.78
Chlorine Total - field	mg/L	APHA4500CIG	0.05	0.80	1.37	1.34	1.32	0.83	1.13	1.00	1.05
Temperature - field	Deg. C	APHA2550B	0.1	23.5	20.3	22.3	21.7	19.5	20.1	20.1	20.5
Dissolved Oxygen - field	mg/L	APHA4500OG	1	8.9	8.8	8.7	8.8	9.1	9.1	9.0	8.8
Turbidity - field#	NTU	APHA2130B	0.1	0.60	0.27	0.27	0.19	0.12	0.15	0.20	0.18
Total Coliforms*#	MPN/100mL	PNWI01	1	<1	<1	<1	<1	<1	<1	<1	<1
<i>E.coli</i> *#	MPN/100mL	PNWI02	1	<1	<1	<1	<1	<1	<1	<1	<1
Total Plate Count*#	cfu/mL	PNWMF03	1	2	<1	<1	<1	<1	<1	1	<1



Certificate Of Analysis

Client: Richmond Valley Council

Report no: 19/1443

Sample No.: Sample description: Date sampled: Time sampled:	Unit	Method	LOR	19/1443/9 Evans Head High Zone 5/09/2019 12:02
pH - field	pH	APHA4500H	2	8.0
Chlorine Free - field	mg/L	APHA4500CIG	0.05	0.56
Chlorine Total - field	mg/L	APHA4500CIG	0.05	0.68
Temperature - field	Deg.C	APHA2550B	0.1	19.8
Dissolved Oxygen - field	mg/L	APHA4500OG	1	9.2
Turbidity - field#	NTU	APHA2130B	0.1	0.16
Total Coliforms*#	MPN/100mL	PNWI01	1	<1
<i>E.coli</i> *#	MPN/100mL	PNWI02	1	<1
Total Plate Count*#	cfu/mL	PNWMF03	1	67

General comments: This report must not be reproduced except in full. This report relates only to items tested as specified herein.
Samples analysed between date received and date reported. Accredited for compliance with ISO/IEC 17025 - Testing
NATA accreditation does not cover the performance of this service. Tests marked with * are subcontracted.
LOR denotes 'Limit of Reporting' < denotes less than; > denotes greater than; ND denotes 'not detected'
The results of the tests, calibrations and/or measurements included in this document are traceable to Australian/national standards

Specific comments: This is the final report that supersedes the preliminary report issued on the 6.9.19

V. Barnett
Laboratory Analyst
Approved Authoriser