



Certificate Of Analysis

Client: Richmond Valley Council
Address: Locked Bag 10
Casino NSW 2470
Contact: Sandeep Chugh
Sampled by: Gary Mead
Subcontract Laboratory: Envirolab (NATA 2901) / UUQ (NATA 11085)
Subcontract Reference: 225595 / 19-08173

Final report

Report no: 19/1445
Date received: 4/09/2019
Testing commenced: 4/09/2019
Date reported: 19/09/2019
No. of samples: 2
Revision no: 00

Analysis results apply to samples as received.

Raw and Finished Mthly

Sample No.: Sample description:	Unit	Method	LOR	19/1445-1 RVC Finished Water 3/09/2019 15:00	19/1445-2 RVC Raw Water 3/09/2019 15:00
Date sampled:					
Time sampled:					
pH	pH	APHA4500H		7.4	7.7
Electrical Conductivity	µS/cm	APHA2510B	1	339	303
Total Dissolved Solids by calc	mg/L	APHA1030E	2	217	194
Fluoride - ISE	mg/L	APHA4500FC	0.05	1.14	[NA]
Colour (Apparent)	Pt-Co	RWL10.02	2	2	20
Colour (True)	Pt-Co	RWL10.02	2	<2	13
Turbidity	NTU	APHA2130B	0.1	<0.10	5.3
Aluminium (Total)	mg/L	APHA3120B	0.005	0.037	0.14
Aluminium (Dissolved)	mg/L	APHA3120B	0.005	0.031	<0.005
Iron (Total)	mg/L	APHA3120B	0.005	<0.005	0.20
Iron (Dissolved)	mg/L	APHA3120B	0.005	<0.005	0.007
Manganese (Total)	mg/L	APHA3120B	0.005	<0.005	0.051
Manganese (Dissolved)	mg/L	APHA3120B	0.005	<0.005	<0.005



Certificate Of Analysis

Client: Richmond Valley Council

Report no: 19/1445

Sample No.: Sample description:	Unit	Method	LOR	19/1445-1 RVC Finished Water 3/09/2019 15:00	19/1445-2 RVC Raw Water 3/09/2019 15:00
Alkalinity (as CaCO ₃)	mg/L	APHA2320B	20	102	101
Suspended Solids	mg/L	APHA2540D	1	<1	6
Total Organic Carbon*	mg/L	Envirolab	1	2	2
Phosphorus - Total	mg/L	RWL 10.07	0.05	<0.05	0.05
Nitrogen - Nitrite-N	mg/L	RWL 10.05	0.01	<0.01	<0.01
Nitrogen - Nitrate-N	mg/L	RWL 10.05	0.05	<0.05	<0.05
Dissolved Organic Carbon*	mg/L	Envirolab	1	2	2
Total Trihalomethanes*	µg/L	Envirolab	1	60	[NA]
2-methylisoborneol*	ng/L	UUQ	2	[NA]	<2
Geosmin*	ng/L	UUQ	2	[NA]	<2
Calcium	mg/L	APHA3120B	0.1	20.3	21.2
Magnesium	mg/L	APHA3120B	0.1	12.8	13.2
Hardness as CaCO ₃	mg/L	APHA2340B	1	103	107
Total Coliforms	MPN/100mL	APHA9223B	1	<1	980
<i>E. coli</i>	MPN/100mL	APHA9223B	1	<1	5
Heterotrophic Plate Count	MPN/mL	APHA9215E	2	<2	623



Certificate Of Analysis

Client: Richmond Valley Council

Report no: 19/1445

General comments: This report must not be reproduced except in full. This report relates to items tested as specified herein.
Samples tested between date received and date reported. Accredited for compliance with ISO/IEC 17025 - Testing
NATA accreditation does not cover the performance of this service. Tests marked with * are subcontracted.
LOR denotes 'Limit of Reporting' < denotes less than; > denotes greater than; ND denotes 'not detected'
The results of the tests, calibrations and/or measurements included in this document are traceable to Australian/national standards

Specific comments:

A. Hawthorne
Laboratory Manager
Approved Authoriser