



## Certificate Of Analysis

**Client:** Richmond Valley Council  
**Address:** Locked Bag 10  
Casino NSW 2470  
**Contact:** Sandeep Chugh  
**Sampled by:** Adrian Leader

Final report

**Report no:** 19/1653  
**Date received:** 9/10/2019  
**Testing commenced:** 9/10/2019  
**Date reported:** 22/10/2019  
**No. of samples:** 3  
**Revision no:** 00

\* **Subcontract Laboratory:** Envirolab (NATA2901)

\* **Subcontract Reference:** 228104

RVC Casino Consumer Monthly

Sampled in accordance with RWL 2.0 to 2.05

Sample No.: Sample description:  Date sampled: Time sampled:	Unit	Method	LOR	19/1653/1 Casino Walker Street 9/10/2019	19/1653/2 Casino Bruton St 9/10/2019	19/1653/3 Casino Council Depot 9/10/2019
Fluoride - ISE	mg/L	APHA4500FC	0.05	1.07	1.07	1.08
Colour (True)	Pt-Co	RWL10.02	2	<2	<2	<2
Ammonia-N	mg/L	RWL 10.06	0.01	0.01	0.01	0.01
Nitrogen - Nitrate-N	mg/L	RWL 10.05	0.05	0.06	0.05	0.05
Nitrogen - Nitrite-N	mg/L	RWL 10.05	0.01	<0.01	<0.01	<0.01
Aluminium (Total)	mg/L	APHA3120B	0.005	0.012	0.007	0.019
Copper (Total)	mg/L	APHA3120B	0.005	0.015	0.012	0.006
Iron (Total)	mg/L	APHA3120B	0.005	0.006	<0.005	<0.005
Lead (Total)	mg/L	APHA3120B	0.005	<0.005	<0.005	<0.005
Manganese (Total)	mg/L	APHA3120B	0.005	<0.005	<0.005	<0.005
Zinc (Total)	mg/L	APHA3120B	0.005	0.005	0.014	0.006
Total Trihalomethanes*	µg/L	Envirolab	1	65	70	73



## Certificate Of Analysis

**Client:** Richmond Valley Council

**Report no:** 19/1653

**General comments:** This report must not be reproduced except in full. This report relates only to items tested as specified herein.  
Samples analysed between date received and date reported. Accredited for compliance with ISO/IEC 17025 - Testing  
# NATA accreditation does not cover the performance of this service. Tests marked with \* are subcontracted.  
LOR denotes 'Limit of Reporting' < denotes less than; > denotes greater than; ND denotes 'not detected'  
The results of the tests, calibrations and/or measurements included in this document are traceable to Australian/national standards

**Specific comments:**

V. Barnett  
Laboratory Analyst  
Approved Authoriser