



Certificate Of Analysis

Client: Richmond Valley Council
Address: Locked Bag 10
Casino NSW 2470
Contact: Sandeep Chugh
Sampled by: Adrian Leader

Final report

Report no: 19/1841
Date received: 6/11/2019
Testing commenced: 6/11/2019
Date reported: 18/11/2019
No. of samples: 3
Revision no: 00

* **Subcontract Laboratory:** Envirolab (NATA2901)

* **Subcontract Reference:** 230437

RVC Consumer Monthly

Sampled in accordance with RWL 2.0 to 2.05

| Sample No.: Sample description: Date sampled: Time sampled: | Unit | Method | LOR | 19/1841/1 Casino Walker Street 6/11/2019 | 19/1841/2 Casino Bruton St 6/11/2019 | 19/1841/3 Casino Council Depot 6/11/2019 |
|--------------------------------------------------------------------------|-------|------------|-------|------------------------------------------------------|-----------------------------------------------|------------------------------------------------------|
| Total Trihalomethanes* | µg/L | Envirolab | 1 | 71 | 69 | 82 |
| Colour (True) | Pt-Co | RWL10.02 | 2 | <2 | <2 | <2 |
| Fluoride - ISE | mg/L | APHA4500FC | 0.05 | 1.13 | 1.08 | 1.06 |
| Aluminium (Total) | mg/L | APHA3120B | 0.005 | 0.033 | 0.056 | 0.048 |
| Iron (Total) | mg/L | APHA3120B | 0.005 | <0.005 | 0.05 | 0.02 |
| Manganese (Total) | mg/L | APHA3120B | 0.005 | <0.005 | <0.005 | <0.005 |
| Copper (Total) | mg/L | APHA3120B | 0.005 | 0.029 | 0.049 | 0.021 |
| Lead (Total) | mg/L | APHA3120B | 0.005 | <0.005 | <0.005 | <0.005 |
| Zinc (Total) | mg/L | APHA3120B | 0.005 | <0.005 | 0.023 | <0.005 |
| Ammonia-N | mg/L | RWL 10.06 | 0.01 | <0.01 | <0.01 | <0.01 |
| Nitrogen - Nitrate-N | mg/L | RWL 10.05 | 0.05 | <0.05 | <0.05 | <0.05 |



Certificate Of Analysis

Client: Richmond Valley Council

Report no: 19/1841

General comments: This report must not be reproduced except in full. This report relates only to items tested as specified herein.
Samples analysed between date received and date reported. Accredited for compliance with ISO/IEC 17025 - Testing
NATA accreditation does not cover the performance of this service. Tests marked with * are subcontracted.
LOR denotes 'Limit of Reporting' < denotes less than; > denotes greater than; ND denotes 'not detected'
The results of the tests, calibrations and/or measurements included in this document are traceable to Australian/national standards

Specific comments:

M Window
Laboratory Analyst
Approved Authoriser