



Certificate Of Analysis

Client: Richmond Valley Council
Address: Locked Bag 10
Casino NSW 2470
Contact: Sandeep Chugh
Sampled by: AL

Final report

Report no: 19/1791
Date received: 30/10/2019
Testing commenced: 30/10/2019
Date reported: 9/11/2019
No. of samples: 8
Revision no: 00

* **Subcontract Laboratory:** NSW Health Pathology

* **Subcontract Reference:** 349534792


RVC Consumer Weekly

Sampled in accordance with RWL 2.0 to 2.05

Sample No.: Sample description:	Unit	Method	LOR	19/1791/1 Casino Sextonville Rd 30/10/2019 11:50	19/1791/2 Casino Walker Street 30/10/2019 12:30	19/1791/3 Coraki Memorial Park 31/10/2019 13:10	19/1791/4 Woodburn Riverside Park 31/10/2019 08:30	19/1791/5 Broadwater Community Centre 31/10/2019 11:25	19/1791/6 Rileys Hill Community Centre 31/10/2019 11:45	19/1791/7 Evans Head School 31/10/2019 09:20	19/1791/8 Evans Head High Zone 31/10/2019 10:10
pH - field	pH	APHA4500H	2	8.0	7.8	7.8	8.2	8.2	8.1	8.1	8.0
Chlorine Free - field	mg/L	APHA4500CIG	0.05	0.99	0.73	0.57	0.55	0.55	0.49	0.46	0.65
Chlorine Total - field	mg/L	APHA4500CIG	0.05	1.12	0.91	0.74	0.65	0.76	0.59	0.81	0.73
Temperature - field	Deg. C	APHA2550B	0.1	26.7	24.6	27.4	23.6	23.5	25.3	23.7	22.5
Dissolved Oxygen - field	mg/L	APHA4500OG	1	7.8	8.3	7.7	8.3	8.2	8.1	8.6	8.4
Turbidity - field#	NTU	APHA2130B	0.1	0.58	0.42	0.25	0.15	0.32	0.27	0.15	0.15
Total Coliforms*#	MPN/100mL	PNWI01	1	<1	<1	<1	<1	<1	<1	<1	<1
<i>E.coli</i> *#	MPN/100mL	PNWI02	1	<1	<1	<1	<1	<1	<1	<1	<1
Total Plate Count*#	cfu/mL	PNWMF03	1	2	13	2	62	1	<1	26	100

General comments: This report must not be reproduced except in full. This report relates only to items tested as specified herein.
Samples analysed between date received and date reported. Accredited for compliance with ISO/IEC 17025 - Testing
NATA accreditation does not cover the performance of this service. Tests marked with * are subcontracted.
LOR denotes 'Limit of Reporting' < denotes less than; > denotes greater than; ND denotes 'not detected'
The results of the tests, calibrations and/or measurements included in this document are traceable to Australian/national standards

Specific comments:


A. Hawthorne
Laboratory Manager
Approved Authoriser