



## Certificate Of Analysis

**Client:** Richmond Valley Council  
**Address:** Locked Bag 10  
Casino NSW 2470  
**Contact:** Sandeep Chugh  
**Sampled by:** Adrian Leader

Final report

**Report no:** 19/2097  
**Date received:** 11/12/2019  
**Testing commenced:** 11/12/2019  
**Date reported:** 23/12/2019  
**No. of samples:** 3  
**Revision no:** 00

\* **Subcontract Laboratory:** Envirolab (NATA2901)

\* **Subcontract Reference:** 233100

RVC Consumer Monthly

Sampled in accordance with RWL 2.0 to 2.05

Sample No.: Sample description:  Date sampled: Time sampled:	Unit	Method	LOR	19/2097/1 Casino Walker Street 11/12/2019	19/2097/2 Casino North Res 11/12/2019	19/2097/3 Casino Sheppard St 11/12/2019
Total Trihalomethanes*	µg/L	Envirolab	1	83	78	107
Colour (True)	Pt-Co	RWL10.02	2	<2	<2	<2
Fluoride - ISE	mg/L	APHA4500FC	0.05	1.06	1.06	1.05
Aluminium (Total)	mg/L	APHA3120B	0.005	<0.005	0.006	0.007
Iron (Total)	mg/L	APHA3120B	0.005	<0.005	<0.005	<0.005
Manganese (Total)	mg/L	APHA3120B	0.005	0.007	0.01	0.006
Copper (Total)	mg/L	APHA3120B	0.005	<0.005	<0.005	<0.005
Lead (Total)	mg/L	APHA3120B	0.005	<0.005	<0.005	<0.005
Zinc (Total)	mg/L	APHA3120B	0.005	<0.005	<0.005	<0.005
Ammonia-N	mg/L	RWL 10.06	0.01	<0.01	<0.01	<0.01
Nitrogen - Nitrate-N	mg/L	RWL 10.05	0.05	0.06	0.06	0.05



## Certificate Of Analysis

**Client:** Richmond Valley Council

**Report no:** 19/2097

General comments: This report must not be reproduced except in full. This report relates only to items tested as specified herein.  
Samples analysed between date received and date reported. Accredited for compliance with ISO/IEC 17025 - Testing  
# NATA accreditation does not cover the performance of this service. Tests marked with \* are subcontracted.  
LOR denotes 'Limit of Reporting' < denotes less than; > denotes greater than; ND denotes 'not detected'  
The results of the tests, calibrations and/or measurements included in this document are traceable to Australian/national standards

Specific comments:

A. Hawthorne  
Laboratory Manager  
Approved Authoriser