



Certificate Of Analysis

Client: Richmond Valley Council
Address: Locked Bag 10
Casino NSW 2470
Contact: Sandeep Chugh
Sampled by: Adrian Leader

Final report

Report no: 19/1989 00
Date received: 27/11/2019
Testing commenced: 27/11/2019
Date reported: 9/12/2019
No. of samples: 2


Sampled in accordance with RWL 2.0 to 2.05

Weekly Fluoride

Sample No.: Sample description:	Unit	Method	LOR	19/1989/1 Casino Walker Street 27/11/2019	19/1989/2 Casino Sextonville Rd 27/11/2019
Fluoride - ISE	mg/L	APHA4500FC	0.05	0.994	1.01
Iron (Total)	mg/L	APHA3120B	0.005	<0.005	0.08
Manganese (Total)	mg/L	APHA3120B	0.005	0.013	0.01

General comments: This report must not be reproduced except in full. This report relates only to the items tested as specified herein.
Samples analysed between date received and date reported. Accredited for compliance with ISO/IEC 17025 - Testing
NATA accreditation does not cover the performance of this service. Tests marked with * are subcontracted.
LOR denotes 'Limit of Reporting' < denotes less than; > denotes greater than; ND denotes 'not detected'
The results of the tests, calibrations and/or measurements included in this document are traceable to Australian/national standards

Specific comments:



A. Hawthorne
Laboratory Manager
Approved Authoriser