



Certificate Of Analysis

Client: Richmond Valley Council
Address: Locked Bag 10
Casino NSW 2470
Contact: Sandeep Chugh
Sampled by: Adrian Leader

Final report

Report no: 20/0452 00
Date received: 11/03/2020
Testing commenced: 11/03/2020
Date reported: 17/03/2020
No. of samples: 3


Sampled in accordance with RWL 2.0 to 2.05

Weekly Fluoride

Sample No.: Sample description:	Unit	Method	LOR	20/0452/1 Casino North Res	20/0452/2 Casino Sheppard St	20/0452/3 Casino Walker Street
Date sampled: Time sampled:				11/03/2020 12:45	11/03/2020 13:00	11/03/2020 12:15
Fluoride - ISE	mg/L	APHA4500FC	0.05	1.03	1.01	1.00
Iron (Total)	mg/L	APHA3120B	0.005	<0.005	0.006	<0.005
Manganese (Total)	mg/L	APHA3120B	0.005	<0.005	<0.005	<0.005

General comments: This report must not be reproduced except in full. This report relates only to the items tested as specified herein. Samples analysed between date received and date reported. Accredited for compliance with ISO/IEC 17025 - Testing # NATA accreditation does not cover the performance of this service. Tests marked with * are subcontracted. LOR denotes 'Limit of Reporting' < denotes less than; > denotes greater than; ND denotes 'not detected' The results of the tests, calibrations and/or measurements included in this document are traceable to Australian/national standards

Specific comments:


A. Hawthorne
Laboratory Manager
Approved Authoriser